

Transmission Losses for the month of Dec2013					
EBC Data					
		INPUT		OUTPUT	
		NET ENERGY in MU		DISCOM	MU
APGENCO	TOTAL	3104.78		220kV/33kV,132kV/33kV,13	
	THERMAL	2734.46		CPDCL	3215.45
	HYDEL	370.32		EPDCL	1139.69
C.G.S				NPDCL	979.14
	CGS (Injection at AP-Periphery)	2730.40		SPDCL	1742.01
	NTPC-SIMHADRI	565.51		Total	7076.30
APGPCL	TOTAL	107.50			
	APGPCL Stage-I	3.49			
	APGPCL Stage-II	104.01			
IPPs	TOTAL	330.28			
	GMR Bargemounted	0.17			
	GVK	102.43			
	Spectrum	125.36			
	Lanco	43.85			
	Reliance	57.11			
	VGPL	-0.61			
	Gowthami	-0.33			
	Konaseema	-0.27			
	SLS Power Corp. Ltd.	2.58			
M.P.Ps	TOTAL	4.61			
	LVS	-0.04			
	Srivatsa	4.64			
CPPs	TOTAL	396.95			
	132KV My Home Cements I & II	9.34			
	Essar Steel Ltd 132 kV Naval Warf	0.04			
	HWP	5.72			
	Kesoram	0.00			
	NBFA # 1 & #2	49.77			
	Navabharath Ventures Ltd Prathipadu	10.73			
	Sitapuram Power Limited	19.93			
	NCS Sugars	7.84			
	Madhucon SPIL 132 kV Kusumanchi	11.30			
	Sarvaraya Sugars Ltd.	5.87			
	BPL 132 kV Sitharampatnam	0.00			
	VSP	0.19			
	Silk Road Sugars	0.00			
	Empee Power Company Ltd.,	4.98			
	Penna Power Limited 132KV Ganeshpahadu#2	29.24			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	7.27			
	VRK Sugars Ltd., 132KV Nallajerla	0.00			
	Krishnaveni sugars	9.69			
	132 kV Madras Cements Ltd.	0.13			
	132KV Laxmi Tulasi	6.09			
	Orient Cement 132 kV	0.03			
	Steel Exchange India Ltd. 132kV	22.20			
	Sarda Metals & Alloys Ltd	48.52			
	NBEIL #1	43.11			
	NBEIL #2	42.66			
	Anrak Aliminium Ltd.	23.40			
	Jaypee Cements	0.00			
	BMM Cements	6.05			
	SBQ Steels	11.15			
	Hetro Wind Power	8.04			
	ICL (Rassi Cements)	0.00			
	Girija Alloy Power Ltd	13.61			
	PSR Green Power Proj. Pvt. Ltd.	0.05			
	KCP	0.00			
Non- Conventional (132 Kv PDs)	TOTAL	68.67			
	220KV ENERCON Wind farms	8.47			
	Agri Gold	-0.02			
	G.S.R.Sugars Pvt Ltd	4.40			

	Ganapathi Sugars Ltd.	5.75				
	GMR Technologies Ltd.	2.39				
	Kakatiya Cement & Sugar Industries Ltd.	6.31				
	Nagarjuna Green Power Ltd. (NGPL)	0.01				
	SNJ Sugars & Products Ltd	4.46				
	Jeypore Sugars Ltd.	3.65				
	AP Paper Mills Ltd.	0.00				
	Nizam Deccan Sugars Ltd.	4.40				
	Shravana Power Projects Pvt. Ltd.	-0.02				
	Enercon Pvt Ltd	6.90				
	SUZLON Wind Farms (Ragulapadu)	8.21				
	SUZLON Wind Farms JMDG-I	3.23				
	SUZLON Wind Farms JMDG-II	3.32				
	RCI Pooling station -Kadavakallu	3.97				
	Rayala Wind farms Feeder	3.23				
Others (132 Kv PDs)	TOTAL	32.42				
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.84				
	Sriba Industries Ltd.	1.85				
	Rain Calcining Ltd.	26.73		Losses	MU	%
				With in State	264.80	3.61
	TOTAL INPUT	7341.10		Total Losses	264.80	3.61
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Jan2014 to 24.00'hours of 25th Feb2014						
* The Transmission Losses are worked out using MRI data.						
* MRI Data considered is from 00.00 Hr of 1st Dec2013 to 24.00 Hr of 31st Dec2013 at 00.30 hr interval.						
* The SR Losses (External Losses to APTRANSCO) for the month of Dec13 is 4.60%						
* Last Year Same month Loss is 3.96%						