



NOTES:-

1. All dimensions are in MM.
2. M20 Concrete Grade shall be used.
3. Tor Steel conforms to IS-415-is-1786
4. Cover to Reinforcement
 - a. Footings: 50MM
 - b. Columns: 40MM
5. Lap: 50Dia
6. Grouting with expansive cement
7. This drg. shall be read WRT CB drg.

TRANSMISSION CORPORATION OF ANDHRA PRADESH

FOUNDATION DETAIL FOR 220kV CB
(for normal soils)

DRG. No.- CE/CIVIL/2CB/FDN/2013