

APTRANSCO Transmission Losses for the month of Mar'2017				
EBC Data				
		INPUT	OUTPUT	
		NET ENERGY in MU	DISCOM	MU
			220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders	
APGENCO	TOTAL	2467.96		
	THERMAL	2228.69	APEPDCL	1734.70
	HYDEL	239.27	APSPDCL	3055.03
C.G.S			Total	4789.73
	CGS (Injection at AP-Periphery)	582.51		
	NTPC-SIMHADRI	635.66		
APGPCL	TOTAL	50.88		
	APGPCL Stage-I	40.03		
	APGPCL Stage-II	10.85		
IPPs	TOTAL	777.04		
	GMR Bargemounted	-0.15		
	GVK	82.13		
	Spectrum	87.40		
	Lanco Kondapalli	100.15		
	Reliance	-0.17		
	VGPL	-0.53		
	Gowthami	-0.38		
	Konaseema	-0.28		
	NCL Energy Ltd., Hospet(T.B.Dam)	0.00		
	Hinduja National Power Corp Ltd	508.87		
M.P.Ps	TOTAL	3.37		
	LVS	-0.04		
	Srivatsa	3.41		
CPPs	TOTAL	93.52		
	Essar Steel Ltd 132 kV Naval Warf	0.00		
	Navabharath Ventures Ltd Prathipadu	9.37		
	NCS Sugars	0.00		
	Sarvaraya Sugars Ltd.	4.22		
	VSP	0.08		
	Silk Road Sugars	1.50		
	Empee Power Company Ltd.,	0.26		
	VRK Sugars Ltd., 132KV Nallajerla	0.00		
	132 kV Madras Cements Ltd(Ramco)	0.03		
	Steel Exchange India Ltd. 132kV	13.15		
	Sarda Metals & Alloys Ltd	15.22		
	Anrak Aliminium Ltd.	0.00		
	Jaypee Cements	0.01		
	BMM Cements	7.67		
	SBQ Steels	8.43		
	Hetro Wind Power	7.89		
	Girija Alloy Power Ltd	21.98		
	Ultratech Cements (L&T)	0.39		
	Bharathi cements Ltd.	0.47		
	Lanco Rachagunneri	0.03		
	Pushpit Steels Pvt.Ltd	0.27		
	Kalyani Gerdau Steels	0.23		
	HPCL Vizag	0.02		
	132KV Sanvra Industries Ltd.	2.30		
	132kV Ramco Cement	0.00		

Non-Conventional (132 Kv PDs)	TOTAL	296.55			
	220KV ENERCON Wind farms	9.17			
	Agri Gold	0.00			
	GMR Technologies Ltd.	0.26			
	SNJ Sugars & Products Ltd	1.52			
	Jeypore Sugars Ltd.	0.00			
	AP Paper Mills Ltd.	0.00			
	Enercon Pvt Ltd	5.53			
	SUZLON Wind Farms F1 (Ragulapadu)	0.00			
	SUZLON Wind Farms F2 (Ragulapadu)	7.29			
	SUZLON Wind Farms JMDG-I	6.08			
	SUZLON Wind Farms JMDG-II	0.63			
	RCI Pooling station -Kadavakallu	4.46			
	Rayala Wind farms Feeder	13.34			
	Gamesa Windfarm(Tagguparthi) - I & II	8.38			
	Mega Engineering Infrastructures Ltd. Solar	5.74			
	Enorgon wind power	9.53			
	R.V.K. Energy Pvt. Ltd. (RJY)	0.00			
	Aarohi Solar Hindupur SS	10.12			
	Azure Solar	8.08			
	Dayanidhi solar	7.18			
	First Solar	7.95			
	Renew Solar Energy(karnataka)Pvt.Ltd	7.57			
	Viswavatham solar	5.69			
	Welspun Feeder Blapanur	6.07			
	Welspun Renewable solar Vemulapadu	12.70			
	Waaneep Solar pvt Ltd.	4.40			
	NP Kunta solar Anatapur	38.37			
	Poly Solar Wind Generator	4.77			
	Suzzlon Windfarms Vajrakarur	14.87			
	Ellutla wind Pooling Station	11.82			
	Suzzlon wind Beluguppa	16.39			
	Ganesa wind Nimbagallu I & II	23.47			
	Mythra Vayu (Thungabadra) Pvt Ltd	9.91			
	Gani Solar Nunnor	34.85			
	Ecoron Wind Energy (Maddela cheruvu pooling station)	0.06			
	M/s Gamesa Renewable Private ltd	0.13			
	Amidyala pooling station	0.09			
	Badrapuram pooling station (Helios)	0.00			
	RTSS Maluguru	0.09			
	Guruve palli pooling station (Vayu vurja Bharath Pvt. Ltd)	0.01			
	East kodi palli pooling station (Saipuram wind energy)	0.00			
	MPR dam pooling station (Axis)	0.00			
	M/s Regen O & M Services Ltd(LV BAY-I)	0.00			
Others (132 Kv PDs)	TOTAL	19.86			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power) (Machilipatnam)	2.16			
	Sriba Industries Ltd.	0.02			
	Rain Calcining Ltd.	17.68	Losses	MU	%
			With in State	137.63	2.79
	TOTAL INPUT	4927.36	Total Losses	137.63	2.79
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Apr'2017 to 24.00'hours of 25th May'2017					
* The Transmission Losses are worked out using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st Mar'2017 to 24.00 Hr of 31st Mar'2017 at 00.30 hr Interval.					
* The SR Losses (External Losses to APTRANSCO) for the month of Mar'2017 is 3.14%					
* Last Year Mar'2016 month Loss is 3.40%					
* Cumulative losses at AP-Peiphery for the FY2016-17 Upto Mar'2017 is 2.92%					
* The Transmission Losses at Ex-Bus (Including SR Losses) for the month Mar'2017 is 3.16%					
* Cumulative losses at CGS EX-BUS for the FY2016-17 Upto Mar'2017 is 3.27%					