

| APTRANSCO Transmission Losses for the month of Oct'2016 | | | | | | |
|---------------------------------------------------------|-----------------------------------------------------------|------------------|--------------------------------------------------------------------|---------|--------|------|
| EBC Data | | | | | | |
| | | INPUT | OUTPUT | | | |
| | | NET ENERGY in MU | DISCOM | MU | | |
| | | | 220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders | | | |
| APGENCO | TOTAL | 2723.21 | | | | |
| | THERMAL | 2450.98 | APEPDCL | 1527.59 | | |
| | HYDEL | 272.23 | APSPDCL | 3091.64 | | |
| C.G.S | | | Total | 4619.22 | | |
| | CGS (Injection at AP-Periphery) | 582.22 | | | | |
| | NTPC-SIMHADRI | 589.88 | | | | |
| APGPCL | TOTAL | 34.17 | | | | |
| | APGPCL Stage-I | 0.29 | | | | |
| | APGPCL Stage-II | 33.88 | | | | |
| IPPs | TOTAL | 509.38 | | | | |
| | GMR Bargemounted | -0.14 | | | | |
| | GVK | 104.69 | | | | |
| | Spectrum | 74.42 | | | | |
| | Lanco Kondapalli | 60.53 | | | | |
| | Reliance | -0.18 | | | | |
| | VGPL | 1.39 | | | | |
| | Gowthami | -0.40 | | | | |
| | Konaseema | -0.27 | | | | |
| | NCL Energy Ltd., Hospet(T.B.Dam) | 0.64 | | | | |
| | Hinduja National Power Corp Ltd | 268.69 | | | | |
| M.P.Ps | TOTAL | 3.20 | | | | |
| | LVS | -0.03 | | | | |
| | Srivatsa | 3.23 | | | | |
| CPPs | TOTAL | 47.71 | | | | |
| | Essar Steel Ltd 132 kV Naval Warf | 0.00 | | | | |
| | Navabharath Ventures Ltd Prathipadu | 0.06 | | | | |
| | NCS Sugars | 0.00 | | | | |
| | Sarvaraya Sugars Ltd. | 0.21 | | | | |
| | VSP | 0.00 | | | | |
| | Silk Road Sugars | 1.66 | | | | |
| | Empee Power Company Ltd., | 0.00 | | | | |
| | VRK Sugars Ltd., 132KV Nallajerla | 0.00 | | | | |
| | 132 kV Madras Cements Ltd(Ramco) | 0.03 | | | | |
| | Steel Exchange India Ltd. 132kV | 4.65 | | | | |
| | Sarda Metals & Alloys Ltd | 11.61 | | | | |
| | Anrak Aluminium Ltd. | 0.00 | | | | |
| | Jaypee Cements | 0.07 | | | | |
| | BMM Cements | 6.72 | | | | |
| | SBQ Steels | 2.72 | | | | |
| | Hetro Wind Power | 8.67 | | | | |
| | Girija Alloy Power Ltd | 6.73 | | | | |
| | Ultratech Cements (L&T) | 1.93 | | | | |
| | Bharathi cements Ltd. | 0.44 | | | | |
| | Lanco Rachagunneri | 0.00 | | | | |
| | Pushpit Steels Pvt.Ltd | 0.21 | | | | |
| | Kalyani Gerdau Steels | 0.31 | | | | |
| | HPCL Vizag | 0.34 | | | | |
| | 132KV Sanvra Industries Ltd. | 1.35 | | | | |
| | 132kV Ramco Cement | 0.00 | | | | |
| Non-Conventional (132 Kv PDs) | TOTAL | 237.65 | | | | |
| | 220KV ENERCON Wind farms | 8.65 | | | | |
| | Agri Gold | 0.00 | | | | |
| | GMR Technologies Ltd. | -0.37 | | | | |
| | SNJ Sugars & Products Ltd | 1.41 | | | | |
| | Jeypore Sugars Ltd. | 0.00 | | | | |
| | AP Paper Mills Ltd. | 0.00 | | | | |
| | Enercon Pvt Ltd | 5.87 | | | | |
| | SUZLON Wind Farms F1 (Ragulapadu) | 0.00 | | | | |
| | SUZLON Wind Farms F2 (Ragulapadu) | 7.44 | | | | |
| | SUZLON Wind Farms JMDG-I | 3.41 | | | | |
| | SUZLON Wind Farms JMDG-II | 3.50 | | | | |
| | RCI Pooling station -Kadavakallu | 4.64 | | | | |
| | Rayala Wind farms Feeder | 18.33 | | | | |
| | Gamesa Windfarm(Tagguparthy) - I & II | 14.56 | | | | |
| | Mega Engineering Infrastructures Ltd. Solar | 3.67 | | | | |
| | Enorgon wind power | 13.82 | | | | |
| | R.V.K. Energy Pvt. Ltd. (RJY) | 0.00 | | | | |
| | Aarohi Solar Hindupur SS | 8.54 | | | | |
| | Azure Solar | 8.10 | | | | |
| | Dayanidhi solar | 6.65 | | | | |
| | First Solar | 7.44 | | | | |
| | Renew Solar Energy(karnataka)Pvt.Ltd | 7.16 | | | | |
| | Viswavatham solar | 5.64 | | | | |
| | Welspun Feeder Blapanur | 5.33 | | | | |
| | Welspun Renewable solar Vemulapadu | 11.08 | | | | |
| | Waaneep Solar pvt Ltd. | 2.67 | | | | |
| | NP Kunta solar Anatapur | 36.48 | | | | |
| | Poly Solar Wind Generator | 5.55 | | | | |
| | Suzzlon Windfarms Vajrakurur | 12.68 | | | | |
| | Ellutla wind Pooling Station | 3.32 | | | | |
| | Suzzlon wind Beluguppa | 10.21 | | | | |
| | Ganesa wind Nimbagallu I & II | 20.47 | | | | |
| | Mythra Vayu (Thungabadra) Pvt Ltd | 1.42 | | | | |
| Others (132 Kv PDs) | TOTAL | 24.37 | | | | |
| | R.V.K. Energy Pvt. Ltd. (G.B.R. Power) (Machilipatnam) | -0.01 | | | | |
| | Sriba Industries Ltd. | -0.01 | | | | |
| | Rain Calcining Ltd. | 24.39 | Losses | MU | | % |
| | | | With in State | | 132.56 | 2.79 |
| | TOTAL INPUT | 4751.78 | Total Losses | | 132.56 | 2.79 |

*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Nov'2016 to 24.00'hours of 25th Dec'2016

* The Transmission Losses are worked out using MRI data.

* MRI Data considered is from 00.00 Hr of 1st Oct'2016 to 24.00 Hr of 31st Oct'2016 at 00.30 hr interval.

* The SR Losses (External Losses to APTRANSCO) for the month of Oct'2016 is 2.57%

* Last Year Oct'2015 month Loss is 3.48%

* Cumulative losses at AP-Peiphery for the FY2016-17 Upto Oct'2016 is 3.00%

* The Transmission Losses at Ex-Bus (Including SR Losses) for the month Oct'2016 is 3.10%

* Cumulative losses at CGS EX-BUS for the FY2016-17 Upto Oct'2016 is 3.34%