

APTRANSCO Transmission Losses for the month of May'2017				
EBC Data				
		INPUT	OUTPUT	
		NET ENERGY in MU	DISCOM	MU
APGENCO	TOTAL	2116.94	220kV/33kV,132kV/33kV, 132/11kV Power Tr. & 220kV,132kV EHT Feeders	
	THERMAL	2032.31	APEPDCL	1866.78
	HYDEL	84.62	APSPDCL	2916.43
C.G.S			Total	4783.21
	CGS (Injection at AP-Periphery)	1364.10		
	NTPC-SIMHADRI	0.00		
APGPCL	TOTAL	122.98		
	APGPCL Stage-I	21.46		
	APGPCL Stage-II	101.52		
IPPs	TOTAL	599.25		
	GMR Bargemounted	-0.14		
	GVK	85.60		
	Spectrum	32.51		
	Lanco Kondapalli	0.12		
	Reliance	0.43		
	VGPL	-1.08		
	Gowthami	-0.34		
	Konaseema	-0.26		
	NCL Energy Ltd., Hospet(T.B.Dam)	0.00		
	Hinduja National Power Corp Ltd	482.39		
M.P.Ps	TOTAL	7.48		
	LVS	-0.04		
	Srivatsa	7.52		
CPPs	TOTAL	55.56		
	Essar Steel Ltd 132 kV Naval Warf	0.00		
	Navabharath Ventures Ltd Prathipadu	0.00		
	NCS Sugars	0.00		
	Sarvaraya Sugars Ltd.	0.00		
	VSP	0.06		
	Silk Road Sugars	1.64		
	Empee Power Company Ltd.,	0.00		
	VRK Sugars Ltd., 132KV Nallajerla	0.00		
	132 kV Madras Cements Ltd(Ramco)	0.04		
	Steel Exchange India Ltd. 132kV	6.86		
	Sarda Metals & Alloys Ltd	13.89		
	Anrak Aliminium Ltd.	0.00		
	Jaypee Cements	0.00		
	BMM Cements	9.47		
	SBQ Steels	2.74		
	Hetro Wind Power	16.15		
	Girija Alloy Power Ltd	1.86		
	Ultratech Cements (L&T)	0.39		
	Bharathi cements Ltd.	0.08		
	Lanco Rachagunneri	0.04		
	Pushpit Steels Pvt.Ltd	0.29		
	Kalyani Gerdau Steels	0.06		
	HPCL Vizag	0.03		
	132KV Sanvra Industries Ltd.	1.95		
	132kV Ramco Cement	0.00		

Non-	TOTAL	659.07			
Conventional	220KV ENERCON Wind farms	19.87			
(132 Kv PDs)	Agri Gold	0.00			
	GMR Technologies Ltd.	0.61			
	SNJ Sugars & Products Ltd	-0.23			
	Jeypore Sugars Ltd.	-0.10			
	AP Paper Mills Ltd.	0.00			
	Enercon Pvt Ltd	11.26			
	SUZLON Wind Farms F1 (Ragulapadu)	0.00			
	SUZLON Wind Farms F2 (Ragulapadu)	17.07			
	SUZLON Wind Farms JMDG-I	12.01			
	SUZLON Wind Farms JMDG-II	0.00			
	RCI Pooling station -Kadavakallu	9.59			
	Rayala Wind farms Feeder	37.36			
	Gamesa Windfarm(Taggunparthy) - I & II	25.63			
	Mega Engineering Infrastructures Ltd. Solar	3.81			
	Enorgon wind power	25.99			
	R.V.K. Energy Pvt. Ltd. (RJY)	0.00			
	Aarohi Solar Hindupur SS	9.48			
	Azure Solar	7.70			
	Dayanidhi solar	7.20			
	First Solar	7.43			
	Renew Solar Energy(karnataka)Pvt.Ltd	6.75			
	Viswavatham solar	5.38			
	Welspun Feeder Blapanur	5.81			
	Welspun Renewable solar Vemulapadu	12.07			
	Waaneep Solar pvt Ltd.	4.11			
	NP Kunta solar Anatapur	37.38			
	Poly Solar Wind Generator	10.41			
	Suzlon Windfarms Vajrakarur	23.94			
	Ellutla wind Pooling Station	27.42			
	Suzlon wind Beluguppa	39.06			
	Ganesa wind Nimbagallu I & II	57.62			
	Mythra Vayu (Thungabadra) Pvt Ltd	31.74			
	Gani Solar Nunnor	124.53			
	Ecoron Wind Energy (Maddela cheruvu pooling station)	15.97			
	M/s Gamesa Renewable Private ltd	22.06			
	Amidyala pooling station	1.52			
	Badrapuram pooling station (Helios)	0.99			
	RTSS Maluguru	0.00			
	Guruve palli pooling station (Vayu vurja Bharath Pvt. Ltd)	0.00			
	East kodi palli pooling station (Saipuram wind energy)	0.00			
	MPR dam pooling station (Axis)	0.04			
	M/s Regen O & M Services Ltd(LV BAY-I)	16.61			
	Ecoron Wind Energy KADAPA	10.06			
	Vinirma wind power	2.56			
	Greenco wind power	8.35			
Others (132 Kv PDs)	TOTAL	21.07			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power) (Machilipatnam)	2.10			
	Sriba Industries Ltd.	-0.02			
	Rain Calcining Ltd.	18.99	Losses	MU	%
			With in State	163.24	3.30
	TOTAL INPUT	4946.44	Total Losses	163.24	3.30
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Jun'2017 to 24.00'hours of 25th Jul'2017					
* The Transmission Losses are worked out using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st May'2017 to 24.00 Hr of 31st May'2017 at 00.30 hr interval.					
* The SR Losses (External Losses to APTRANSCO) for the month of May'2017 is 3.23%					
* Last Year May'2016 month Loss is 3.13%					
* Cumulative losses at AP-Peiphery for the FY2017-18 Upto May'2017 is 3.34%					
* The Transmission Losses at Ex-Bus (Including SR Losses) for the month May'2017 is 4.18%					
* Cumulative losses at CGS EX-BUS for the FY2017-18 Upto May'2017 is 4.10%					