

APTRANSCO Transmission Losses for the month of June 2014					
EBC Data					
		INPUT NET ENERGY in MU	OUTPUT		
			DISCOM	MU	
APGENCO	TOTAL	1650.98	220kV/33kV,132kV/33kV,13		
	THERMAL	1559.79	APEPDCL	1284.40	
	HYDEL	91.19	APSPDCL	2327.46	
C.G.S			Total	3611.86	
	CGS (Injection at AP-Periphery)	622.95			
APGPCL	NTPC-SIMHADRI	668.72			
	TOTAL	76.11			
	APGPCL Stage-I	0.05			
IPPs	APGPCL Stage-II	76.05			
	TOTAL	255.60			
M.P.Ps	GMR Bargemounted	-0.18			
	GVK	49.08			
	Spectrum	62.52			
	Lanco	111.87			
	Reliance	33.61			
	VGPL	-0.60			
	Gowthami	-0.36			
	Konaseema	-0.32			
	NCL Energy Ltd., Hospet(T.B.Dam)	0.00			
	TOTAL	3.69			
	LVS	-0.03			
	CPPs	Srivatsa	3.72		
TOTAL		236.55			
Non-Conventional (132 Kv PDs)	Essar Steel Ltd 132 kV Naval Warf	0.01			
	Navabharath Ventures Ltd Prathipadu	12.63			
	NCS Sugars	9.75			
	Sarvaraya Sugars Ltd.	0.00			
	VSP	0.03			
	Silk Road Sugars	0.00			
	Empee Power Company Ltd.,	0.00			
	VRK Sugars Ltd., 132KV Nallajerla	0.00			
	132 kV Madras Cements Ltd.	0.79			
	Steel Exchange India Ltd. 132kV	25.56			
	Sarda Metals & Alloys Ltd	25.71			
	Anrak Aluminium Ltd.	78.20			
	Jaypee Cements	0.74			
	BMM Cements	10.41			
	SBQ Steels	17.18			
	Hetro Wind Power	22.19			
	Girija Alloy Power Ltd	33.35			
Others (132 Kv PDs)	TOTAL	188.52			
	220KV ENERCON Wind farms	36.27			
	Agri Gold	-0.02			
	GMR Technologies Ltd.	-0.28			
	SNJ Sugars & Products Ltd	-0.77			
	Jeypore Sugars Ltd.	-0.07			
	AP Paper Mills Ltd.	0.00			
	Enercon Pvt Ltd	31.44			
	SUZLON Wind Farms (Ragulapadu)	31.43			
	SUZLON Wind Farms JMDG-I	13.80			
	SUZLON Wind Farms JMDG-II	14.16			
	RCI Pooling station -Kadavakallu	17.78			
	Rayala Wind farms Feeder	43.13			
	Gamesa Windfarm(Tagguparthy)	1.67			
TOTAL	30.99				
R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.24				
Sriba Industries Ltd.	1.74				
Rain Calcining Ltd.	26.01		Losses	MU %	
			With in State	122.26 3.27	
			Total Losses	122.26 3.27	
TOTAL INPUT	3734.12				

*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th July2014 to 24.00'hours of 25th Aug2014

* The Transmission Losses are worked out using MRI data.

* MRI Data considered is from 00.00 Hr of 1st June2014 to 24.00 Hr of 30th June2014 at 00.30 hr interval.

* The SR Losses (External Losses to APTRANSCO) for the month of June14 is 3.66%

* Last Year Same month Loss is 3.53 %

* Cumulative losses at AP-Peiphery FY2014-15 Upto June2014 is 3.79%