

Transmission Losses for the month of November 2010					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
APGENCO	TOTAL	2961.02	220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders		
	THERMAL	2162.06	CPDCL	2463.75	
	HYDEL	798.96	EPDCL	878.33	
C.G.S			NPDCL	702.37	
	CGS (Ex-Bus)	233.28	SPDCL	1157.78	
	NTPC-SIMHADRI	612.12	Total	5202.22	
APGPCL	TOTAL	116.52			
	APGPCL Stage-I	5.65			
	APGPCL Stage-II	110.88			
IPPs	TOTAL	1341.73			
	GMR Bargemounted	112.57			
	GVK	228.37			
	Spectrum	100.62			
	Lanco	172.38			
	Reliance	75.48			
	VGPL	198.97			
	Gowthami	232.12			
	Konaseema	221.22			
M.P.Ps	TOTAL	4.85			
	LVS	-0.04			
	Srivatsa	4.88			
CPPs	TOTAL	124.27			
	Essar Steel Ltd 132 kV Naval Warf	0.00			
	HWP	1.01			
	Kesoram	0.20			
	NBFA # 1	50.43			
	NBFA # 2	11.18			
	Sitapuram Power Limited	4.57			
	NCS Sugars	5.17			
	Madhucon SPIL 132 kV Kusumanchi	12.79			
	Sarvaraya Sugars Ltd.	4.09			
	BPL 132 kV Sitharampatnam	1.88			
	VSP	0.04			
	Silk Road Sugars	6.72			
	Empee Power Company Ltd.,	4.11			
	Penna Power Limited	19.36			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.71			
Non-Conventional (132 Kv PDs)	TOTAL	20.33			
	Clarion Power Corporation Ltd	-0.20			
	G.S.R.Sugars Pvt Ltd	-0.09			
	Ganapathi Sugars Ltd.	-0.13			
	GMR Technologies Ltd.	4.56			
	Kakatiya Cement & Sugar Industries Ltd.	4.46			
	Nagarjuna Green Power Ltd. (NGPL)	3.81			
	Sagar Sugar & Allied Products Ltd.	0.86			
	Jeypore Sugars Ltd.	0.51			
	AP Paper Mills Ltd.	2.77			
	Nizam Deccan Sugars Ltd.	-0.08			
	Shravana Power Projects Pvt. Ltd.	3.85			
Others (132 Kv PDs)	TOTAL	33.16			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.25			
	Sriba Industries Ltd.	5.77	External to APTransco at 7.45%	17.38	0.32
	Rain Calcining Ltd.	24.14	With in State	227.67	4.18
	TOTAL INPUT	5447.27	Total Losses	245.05	4.50

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

* MRI Data considered is from 00.00 Hr of 1st Nov 2010 to 24.00 Hr of 30th Nov 2010 at 00.30 hr interval.

* Last Year Same month Loss is 5.36 %