

Transmission Losses for the month of October 2010				
EBC Data				
		INPUT	OUTPUT	
		NET ENERGY in MU	DISCOM	MU
APGENCO	TOTAL	3362.56	220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders	
	THERMAL	2073.10	CPDCL	2940.46
	HYDEL	1289.46	EPDCL	969.28
C.G.S			NPDCL	913.05
	CGS (Ex-Bus)	558.41	SPDCL	1420.39
	NTPC-SIMHADRI	677.86	Total	6243.18
APGPCL	TOTAL	119.88		
	APGPCL Stage-I	13.10		
	APGPCL Stage-II	106.78		
IPPs	TOTAL	1652.09		
	GMR Bargemounted	116.83		
	GVK	274.81		
	Spectrum	135.94		
	Lanco	210.30		
	Reliance	136.56		
	VGPL	247.84		
	Gowthami	296.70		
	Konaseema	233.11		
M.P.Ps	TOTAL	8.48		
	LVS	-0.04		
	Srivatsa	8.52		
CPPs	TOTAL	140.60		
	Essar Steel Ltd 132 kV Naval Warf	0.01		
	HWP	1.18		
	Kesoram	0.00		
	NBFA # 1	45.26		
	NBFA # 2	12.65		
	Sitapuram Power Limited	15.49		
	NCS Sugars	4.12		
	Madhucon SPIL 132 kV Kusumanchi	13.28		
	Sarvaraya Sugars Ltd.	4.06		
	BPL 132 kV Sitharampatnam	1.75		
	VSP	0.19		
	Silk Road Sugars	5.67		
	Empee Power Company Ltd.,	4.31		
	Penna Power Limited	30.51		
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.12		
Non-Conventional (132 Kv PDs)	TOTAL	20.35		
	Clarion Power Corporation Ltd	2.26		
	G.S.R.Sugars Pvt Ltd	0.60		
	Ganapathi Sugars Ltd.	-0.09		
	GMR Technologies Ltd.	2.29		
	Kakatiya Cement & Sugar Industries Ltd.	-0.11		
	Nagarjuna Green Power Ltd. (NGPL)	2.03		
	Sagar Sugar & Allied Products Ltd.	-0.08		
	Jeypore Sugars Ltd.	0.00		
	AP Paper Mills Ltd.	3.08		
	Nizam Deccan Sugars Ltd.	6.85		
	Shravana Power Projects Pvt. Ltd.	3.53		
Others (132 Kv PDs)	TOTAL	35.07		
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.56	Losses	MU
	Sriba Industries Ltd.	6.94	External to APTransco at 6.06%	33.84
	Rain Calcining Ltd.	24.57	With in State	298.27
	TOTAL INPUT	6575.29	Total Losses	332.11
				5.05

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

* MRI Data considered is from 00.00 Hr of 1st Oct 2010 to 24.00 Hr of 31st Oct 2010 at 00.30 hr interval.

* Last Year Same month Loss is 5.15 %