

**Transmission Losses for the month of Nov2011**

**EBC Data**

		INPUT NET ENERGY in MU	OUTPUT DISCOM MU
APGENCO	TOTAL	3119.02	220kV/33kV,132kV/33kV,
	THERMAL	2808.63	CPDCL 2970.45
	HYDEL	310.39	EPDCL 1034.72
C.G.S			NPDCL 956.77
	CGS ( Injection at AP-Periphery)	1488.89	SPDCL 1404.80
	NTPC-SIMHADRI	452.58	Total 6366.73
APGPCL	TOTAL	126.78	
	APGPCL Stage-I	11.82	
	APGPCL Stage-II	114.97	
IPPs	TOTAL	1278.90	
	GMR Bargemounted	95.16	
	GVK	222.54	
	Spectrum	91.24	
	Lanco	209.12	
	Reliance	93.17	
	VGPL	173.14	
	Gowthami	208.13	
	Konaseema	186.40	
M.P.Ps	TOTAL	7.97	
	LVS	-0.04	
	Srivatsa	8.01	
CPPs	TOTAL	109.33	
	Essar Steel Ltd 132 kV Naval Warf	0.00	
	HWP	0.86	
	Kesoram	0.00	
	NBFA # 1	36.29	
	NBFA # 2	0.00	
	Sitapuram Power Limited	14.60	
	NCS Sugars	11.21	
	Madhucon SPIL 132 kV Kusumanchi	5.32	
	Sarvaraya Sugars Ltd.	3.98	
	BPL 132 kV Sitharampatnam	0.00	
	VSP	0.15	
	Silk Road Sugars	0.00	
	Empee Power Company Ltd.,	1.61	
	Penna Power Limited 132KV Ganeshpahadu#2	24.72	
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.74	
	VRK Sugars Ltd., 132KV Nallajerla	0.00	
	Krishnaveni sugars	5.82	

Non- Conventio nal (132 Kv PDs)	TOTAL	29.60			
	Clarion Power Corporation Ltd	1.13			
	G.S.R.Sugars Pvt Ltd	1.12			
	Ganapathi Sugars Ltd.	1.32			
	GMR Technologies Ltd.	1.84			
	Kakatiya Cement & Sugar Industries Ltd.	7.95			
	Nagarjuna Green Power Ltd. (NGPL)	3.29			
	Sagar Sugar & Allied Products Ltd.	2.69			
	Jeypore Sugars Ltd.	-0.02			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	-0.07			
Shravana Power Projects Pvt. Ltd.	4.01				
Enercon Pvt Ltd	6.35				
Others (132 Kv PDs)	TOTAL	35.57			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.82			
	Sriba Industries Ltd.	3.88			
	Rain Calcining Ltd.	27.87			
			<b>Losses</b>	<b>MU</b>	<b>%</b>
			With in State	281.91	4.24
			<b>Total Losses</b>	<b>281.91</b>	<b>4.24</b>
	<b>TOTAL INPUT</b>	<b>6648.64</b>			

\* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

\* MRI Data considered is from 00.00 Hr of 1stNov 2011 to 24.00 Hr of 30th Nov2011 at 00.30 hr interval.

\* The SR Losses (External Losses to APTRANSCO) for the month of Nov11 is 4.72%

\* Last Year Same month Loss is 4.19 %

**Transmission Losses for the month of Nov2011**

**EBC Data**

		<b>INPUT NET ENERGY in MU</b>	<b>OUTPUT</b>
			<b>DISCOM                  MU</b>
<b>APGENCO</b>	<b>TOTAL</b>	<b>3119.02</b>	220kV/33kV,132kV/33kV,1
	THERMAL	2808.63	CPDCL                  2970.45
	HYDEL	310.39	EPDCL                  1034.72
<b>C.G.S</b>			NPDCL                  956.77
	CGS ( Ex-Bus)	<b>1562.67</b>	SPDCL                  1404.80
	NTPC-SIMHADRI	452.58	<b>Total                  6366.73</b>
<b>APGPCL</b>	<b>TOTAL</b>	<b>126.78</b>	
	APGPCL Stage-I	11.82	
	APGPCL Stage-II	114.97	
<b>IPPs</b>	<b>TOTAL</b>	<b>1278.90</b>	
	GMR Bargemounted	95.16	
	GVK	222.54	
	Spectrum	91.24	
	Lanco	209.12	
	Reliance	93.17	
	VGPL	173.14	
	Gowthami	208.13	
	Konaseema	186.40	
<b>M.P.Ps</b>	<b>TOTAL</b>	<b>7.97</b>	
	LVS	-0.04	
	Srivatsa	8.01	
<b>CPPs</b>	<b>TOTAL</b>	<b>109.33</b>	
	Essar Steel Ltd 132 kV Naval Warf	0.00	
	HWP	0.86	
	Kesoram	0.00	
	NBFA # 1	36.29	
	NBFA # 2	0.00	
	Sitapuram Power Limited	14.60	
	NCS Sugars	11.21	
	Madhucon SPIL 132 kV Kusumanchi	5.32	
	Sarvaraya Sugars Ltd.	3.98	
	BPL 132 kV Sitharampatnam	0.00	
	VSP	0.15	
	Silk Road Sugars	0.00	
	Empee Power Company Ltd.,	1.61	
	Penna Power Limited 132KV Ganeshpahadu#1 & #2	24.72	
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.74	
	VRK Sugars Ltd., 132KV Nallajerla	0.00	
	Krishnaveni sugars	5.82	

<b>Non-Convention al (132 Kv PDs)</b>	<b>TOTAL</b>	<b>29.60</b>			
	Clarion Power Corporation Ltd	1.13			
	G.S.R.Sugars Pvt Ltd	1.12			
	Ganapathi Sugars Ltd.	1.32			
	GMR Technologies Ltd.	1.84			
	Kakatiya Cement & Sugar Industries Ltd.	7.95			
	Nagarjuna Green Power Ltd. (NGPL)	3.29			
	Sagar Sugar & Allied Products Ltd.	2.69			
	Jeypore Sugars Ltd.	-0.02			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	-0.07			
	Shravana Power Projects Pvt. Ltd.	4.01			
	Enercon Pvt Ltd	6.35			
<b>Others (132 Kv PDs)</b>	<b>TOTAL</b>	<b>35.57</b>			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.82			
	Sriba Industries Ltd.	3.88			
	Rain Calcining Ltd.	27.87			
	<b>TOTAL INPUT</b>	<b>6722.43</b>			
			<b>Losses</b>	<b>MU</b>	<b>%</b>
			External to		
			APTransco at		
			4.72%	73.76	1.10
			With in State	281.94	4.19
			<b>Total Losses</b>	<b>355.70</b>	<b>5.29</b>

\* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

\* MRI Data considered is from 00.00 Hr of 1stNov 2011 to 24.00 Hr of 30th Nov2011 at 00.30 hr interval.

\* Last Year Same month Loss is 4.50%