

Transmission Losses for the month of May 2010

EBC Data

		INPUT	OUTPUT	
		NET ENERGY in MU	DISCOM	MU
APGENCO	TOTAL	2483.19	220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders	
	THERMAL	2263.21	CPDCL	2743.984
	HYDEL	219.98	EPDCL	974.0113
C.G.S			NPDCL	694.6902
	CGS ( Injec	1197.228	SPDCL	1371.408
	NTPC-SIMH	655.1911	Total	5784.094
APGPCL	TOTAL	168.089		
	APGPCL S	56.26316		
	APGPCL S	111.8258		
IPPs	TOTAL	1399.065		
	GVK	281.1606		
	Spectrum	141.1508		
	Lanco	123.2952		
	Reliance	138.436		
	VGPL	236.201		
	Gowthami	299.9608		
	Konaseema	178.8611		
M.P.Ps	TOTAL	19.95738		
	LVS	12.49936		
	Srivatsa	7.45802		
CPPs	TOTAL	144.7534		
	Essar Steel	0.01		
	HWP	2.86		
	Kesoram	1.02		
	NBFA # 1	50.47		
	NBFA # 2	12.71		
	Sitapuram	19.17337		
	NCS Sugar	12.61		
	Madhucon	14.4		
	Sarvaraya S	6.21		
	BPL 132 kV	2.21		
	VSP	0.27		
	Silk Road S	0		
	Empee Pov	2.87		
	Penna Pow	15.66		
	Shalivahan	4.28		
Non-Conve	TOTAL	26.88845		
	Clarion Pov	5.86923		
	G.S.R.Sugr	-0.04		
	Ganapathi	-0.08		
	GMR Tech	-0.2		
	Kakatiya Cr	9.074045		
	Nagarjuna	4.09657		
	Sagar Sugr	4.9086		
	Jeypore Su	-0.06		
	AP Paper M	3.61		
	Nizam Deci	-0.29		
Others (13:	TOTAL	38.72409		
	R.V.K. Ene	3.9994		
	Sriba Indus	8.977335	Losses	MU %
	Rain Calcir	25.74735	With in Sta	348.9961 5.69038
	TOTAL INF	6133.09	Total Losse	348.9961 5.69038

\* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

\* MRI Data considered is from 00.00 Hr of 1st May 2010 to 24.00 Hr of 31st May 2010 at 00.30 hr interval.

\* Last Year Same month Loss is 6.20 %