

Transmission Losses for the month of Dec2011					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
			220kV/33kV,132kV/33kV,132/11 kV Power Tr. & 220kV,132kV		
APGENCO	TOTAL	3102.07			
	THERMAL	2917.58	CPDCL	2999.54	
	HYDEL	184.50	EPDCL	991.25	
C.G.S			NPDCL	959.85	
	CGS (Injection at AP-Periphery)	1488.16	SPDCL	1410.11	
	NTPC-SIMHADRI	482.41	Total	6360.75	
APGPCL	TOTAL	118.94			
	APGPCL Stage-I	0.07			
	APGPCL Stage-II	118.86			
IPPs	TOTAL	1205.52			
	GMR Bargemounted	88.48			
	GVK	214.36			
	Spectrum	105.06			
	Lanco	166.67			
	Reliance	110.69			
	VGPL	153.50			
	Gowthami	203.53			
	Konaseema	163.23			
M.P.Ps	TOTAL	8.24			
	LVS	-0.04			
	Srivatsa	8.28			
CPPs	TOTAL	145.89			
	Essar Steel Ltd 132 kV Naval Warf	0.00			
	HWP	0.30			
	Kesoram	0.28			
	NBFA # 1	47.20			
	NBFA # 2	0.00			
	Sitapuram Power Limited	10.80			
	NCS Sugars	9.35			
	Madhucon SPIL 132 kV Kusumanchi	13.67			
	Sarvaraya Sugars Ltd.	5.39			
	BPL 132 kV Sitharampatnam	0.00			
	VSP	0.17			
	Silk Road Sugars	0.00			
	Empee Power Company Ltd.,	4.11			
	Penna Power Limited 132KV Ganeshpahadu	36.88			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	5.61			
	VRK Sugars Ltd., 132KV Nallajerla	0.00			
	Krishnaveni sugars	12.14			
Non-Conventional (132 Kv PDs)	TOTAL	46.49			
	Clarion Power Corporation Ltd	0.89			
	G.S.R.Sugars Pvt Ltd	4.37			
	Ganapathi Sugars Ltd.	6.43			
	GMR Technologies Ltd.	2.01			
	Kakatiya Cement & Sugar Industries Ltd.	6.74			
	Nagarjuna Green Power Ltd. (NGPL)	0.89			
	Sagar Sugar & Allied Products Ltd.	4.50			
	Jeypore Sugars Ltd.	5.83			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	4.23			
	Shravana Power Projects Pvt. Ltd.	4.95			
	Enercon Pvt Ltd	5.63			
Others (132 Kv PDs)	TOTAL	33.11			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.38			
	Sriba Industries Ltd.	3.61			
	Rain Calcining Ltd.	26.11	Losses	MU	%
			With in State	270.07	4.07
	TOTAL INPUT	6630.82	Total Losses	270.07	4.07

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

* MRI Data considered is from 00.00 Hr of 1stDec 2011 to 24.00 Hr of 31st Dec2011 at 00.30 hr interval.

* The SR Losses (External Losses to APTRANSCO) for the month of Dec11 is 5.18%

* Last Year Same month Loss is 4.61 %