

Transmission Losses for the month of Feb2012 (applicable for OA users effective from 00'hrs of 26th Mar12 to 24'hrs of 25th Apr12)

| EBC Data | | | | | |
|-------------------------------|--|------------------|--|------------------------|-------------|
| | | INPUT | | OUTPUT | |
| | | NET ENERGY in MU | | DISCOM | MU |
| APGENCO | TOTAL | 3286.93 | | 220kV/33kV,132kV/33kV, | |
| | THERMAL | 2911.64 | | CPDCL | 3142.91 |
| | HYDEL | 375.29 | | EPDCL | 1015.61 |
| C.G.S | | | | NPDCL | 1064.32 |
| | CGS (Injection at AP-Periphery) | 1699.56 | | SPDCL | 1507.80 |
| | NTPC-SIMHADRI | 659.70 | | Total | 6730.65 |
| APGPCL | TOTAL | 108.87 | | | |
| | APGPCL Stage-I | 0.18 | | | |
| | APGPCL Stage-II | 108.69 | | | |
| IPPs | TOTAL | 1003.18 | | | |
| | GMR Bargemounted | 66.52 | | | |
| | GVK | 178.88 | | | |
| | Spectrum | 90.48 | | | |
| | Lanco | 182.85 | | | |
| | Reliance | 80.78 | | | |
| | VGPL | 115.02 | | | |
| | Gowthami | 154.92 | | | |
| | Konaseema | 133.73 | | | |
| M.P.Ps | TOTAL | 6.38 | | | |
| | LVS | -0.04 | | | |
| | Srivatsa | 6.41 | | | |
| CPPs | TOTAL | 187.50 | | | |
| | Essar Steel Ltd 132 kV Naval Warf | 0.01 | | | |
| | HWP | 7.57 | | | |
| | Kesoram | 1.18 | | | |
| | NBFA # 1 | 63.09 | | | |
| | NBFA # 2 | 11.07 | | | |
| | Sitapuram Power Limited | 16.14 | | | |
| | NCS Sugars | 9.01 | | | |
| | Madhucon SPIL 132 kV Kusumanchi | 13.21 | | | |
| | Sarvaraya Sugars Ltd. | 5.22 | | | |
| | BPL 132 kV Sitharampatnam | 0.00 | | | |
| | VSP | 0.21 | | | |
| | Silk Road Sugars | 0.00 | | | |
| | Empee Power Company Ltd., | 5.06 | | | |
| | Penna Power Limited 132KV Ganeshpahu#2 | 39.88 | | | |
| | Shalivahana (MSW) Green Energy Pvt. Ltd. | 4.71 | | | |
| | VRK Sugars Ltd., 132KV Nallajerla | 0.00 | | | |
| | Krishnaveni sugars | 11.14 | | | |
| Non-Conventional (132 Kv PDs) | TOTAL | 41.39 | | | |
| | Clarion Power Corporation Ltd | 1.27 | | | |
| | G.S.R.Sugars Pvt Ltd | 3.29 | | | |
| | Ganapathi Sugars Ltd. | 5.81 | | | |
| | GMR Technologies Ltd. | 2.70 | | | |
| | Kakatiya Cement & Sugar Industries Ltd. | 4.76 | | | |
| | Nagarjuna Green Power Ltd. (NGPL) | -0.01 | | | |
| | Sagar Sugar & Allied Products Ltd. | 4.45 | | | |
| | Jeypore Sugars Ltd. | 5.35 | | | |
| | AP Paper Mills Ltd. | 0.00 | | | |
| | Nizam Deccan Sugars Ltd. | 1.86 | | | |
| | Shravana Power Projects Pvt. Ltd. | 4.21 | | | |
| | Enercon Pvt Ltd | 7.70 | | | |
| Others (132 Kv PDs) | TOTAL | 31.65 | | | |
| | R.V.K. Energy Pvt. Ltd. (G.B.R. Power) | 3.05 | | | |
| | Sriba Industries Ltd. | 4.55 | | | |
| | Rain Calcining Ltd. | 24.05 | | Losses | MU % |
| | | | | With in State | 294.51 4.19 |
| | TOTAL INPUT | 7025.16 | | Total Losses | 294.51 4.19 |

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

* MRI Data considered is from 00.00 Hr of 1stFeb 2012 to 24.00 Hr of 29th Feb2012 at 00.30 hr interval.

* The SR Losses (External Losses to APTRANSCO) for the month of Feb12 is 5.39%

* Last Year Same month Loss is 4.60 %