

Transmission Losses for the month of Jan2012					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
			220kV/33kV,132kV/33kV,132/11 kV Power Tr. & 220kV,132kV		
APGENCO	TOTAL	3324.18			
	THERMAL	3002.64	CPDCL	3230.28	
	HYDEL	321.54	EPDCL	1044.53	
C.G.S			NPDCL	1067.41	
	CGS (Injection at AP-Periphery)	1570.73	SPDCL	1479.20	
	NTPC-SIMHADRI	664.57	Total	6821.42	
APGPCL	TOTAL	115.39			
	APGPCL Stage-I	0.07			
	APGPCL Stage-II	115.32			
IPPs	TOTAL	1176.31			
	GMR Bargemounted	77.27			
	GVK	205.30			
	Spectrum	104.60			
	Lanco	209.46			
	Reliance	101.60			
	VGPL	144.30			
	Gowthami	185.50			
	Konaseema	148.29			
M.P.Ps	TOTAL	6.98			
	LVS	-0.04			
	Srivatsa	7.02			
CPPs	TOTAL	191.59			
	Essar Steel Ltd 132 kV Naval Warf	0.03			
	HWP	7.01			
	Kesoram	0.62			
	NBFA # 1	66.58			
	NBFA # 2	12.98			
	Sitapuram Power Limited	11.28			
	NCS Sugars	8.12			
	Madhucon SPIL 132 kV Kusumanchi	13.99			
	Sarvaraya Sugars Ltd.	5.58			
	BPL 132 kV Sitharampatnam	0.00			
	VSP	0.10			
	Silk Road Sugars	0.00			
	Empee Power Company Ltd.,	4.91			
	Penna Power Limited 132KV Ganeshpahadu	42.38			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	5.90			
	VRK Sugars Ltd., 132KV Nallajerla	0.00			
	Krishnaveni sugars	12.10			
Non-Conventional (132 Kv PDs)	TOTAL	42.53			
	Clarion Power Corporation Ltd	1.03			
	G.S.R.Sugars Pvt Ltd	3.78			
	Ganapathi Sugars Ltd.	6.24			
	GMR Technologies Ltd.	2.26			
	Kakatiya Cement & Sugar Industries Ltd.	4.47			
	Nagarjuna Green Power Ltd. (NGPL)	-0.03			
	Sagar Sugar & Allied Products Ltd.	4.48			
	Jeypore Sugars Ltd.	4.49			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	4.61			
	Shravana Power Projects Pvt. Ltd.	4.11			
	Enercon Pvt Ltd	7.08			
Others (132 Kv PDs)	TOTAL	31.81			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.21			
	Sriba Industries Ltd.	5.39			
	Rain Calcining Ltd.	23.21	Losses	MU	%
			With in State	302.67	4.25
	TOTAL INPUT	7124.09	Total Losses	302.67	4.25
* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.					
* MRI Data considered is from 00.00 Hr of 1stJan 2012 to 24.00 Hr of 31st Jan2012 at 00.30 hr interval.					
* The SR Losses (External Losses to APTRANSCO) for the month of Jan12 is 5.33%					
* Last Year Same month Loss is 4.71 %					