

Transmission Losses for the month of Jan2013(applicable for OA users effective from 00'hrs of 26th Feb13 to 24'hrs of 25th Mar13)					
EBC Data					
INPUT			OUTPUT		
	NET ENERGY in MU		DISCOM	MU	
APGENCO	TOTAL	3290.16	220kV/33kV,132kV/33kV,132/11k		
	THERMAL	3016.50	CPDCL	3161.76	
	HYDEL	273.66	EPDCL	1058.17	
C.G.S			NPDCL	1037.06	
	CGS (Injection at AP-Periphery)	2342.17	SPDCL	1596.23	
	NTPC-SIMHADRI	679.56	Total	6853.23	
APGPCL	TOTAL	82.66			
	APGPCL Stage-I	0.11			
	APGPCL Stage-II	82.55			
IPPs	TOTAL	430.44			
	GMR Bargemounted	12.87			
	GVK	90.21			
	Spectrum	77.57			
	Lanco	121.24			
	Reliance	38.90			
	VGPL	32.01			
	Gowthami	34.41			
	Konaseema	23.23			
M.P.Ps	TOTAL	3.12			
	LVS	-0.04			
	Srivatsa	3.16			
CPPs	TOTAL	229.71			
	132KV My Home Cements I & II	12.47			
	Essar Steel Ltd 132 kV Naval Warf	0.04			
	HWP	6.85			
	Kesoram	0.90			
	NBFA # 1	53.59			
	NBFA # 2	13.21			
	Sitapuram Power Limited	16.90			
	NCS Sugars	8.08			
	Madhucon SPIL 132 kV Kusumanchi	13.38			
	Sarvaraya Sugars Ltd.	5.63			
	BPL 132 kV Sitharampatnam	0.17			
	VSP	0.11			
	Silk Road Sugars	0.00			
	Empee Power Company Ltd.	5.54			
	Penna Power Limited 132KV Ganeshpahu#2	43.43			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	7.56			
	VRK Sugars Ltd., 132KV Nallajerla	0.00			
	Krishnaveni sugars	12.24			
	132 kV Madras Cements Ltd.	0.73			
	132KV Laxmi Tulasi	6.11			
	Orient Cement 132 kV	3.62			
	Steel Exchange India Ltd. 132kV	19.14			
Non-Conventional (132 Kv PDs)	TOTAL	55.37			
	220KV ENERCON Wind farms	4.86			
	Agri Gold	-0.03			
	G.S.R.Sugars Pvt Ltd	3.90			
	Ganapathi Sugars Ltd.	5.86			
	GMR Technologies Ltd.	3.24			
	Kakatiya Cement & Sugar Industries Ltd.	4.90			
	Nagarjuna Green Power Ltd. (NGPL)	0.01			
	Sagar Sugar & Allied Products Ltd.	4.42			
	Jeypore Sugars Ltd.	2.70			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	3.60			
	Shravana Power Projects Pvt. Ltd.	1.71			
	Enercon Pvt Ltd	6.90			
	SUZLON Wind Farms (Ragulapadu)	9.10			
	SUZLON Wind Farms (Yerraguntla)	4.21			
Others (132 Kv PDs)	TOTAL	31.62			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	5.01			
	Sriba Industries Ltd.	2.79			
	Rain Calcining Ltd.	23.81			
	TOTAL INPUT	7144.83	Losses	MU	%
			With in State	291.60	4.08
			Total Losses	291.60	4.08

* The Transmission Losses are worked out using MRI data.
* MRI Data considered is from 00.00 Hr of 1st Jan2013 to 24.00 Hr of 31st Jan2013 at 00.30 hr interval.
* The SR Losses (External Losses to APTRANSCO) for the month of Jan13 is 4.40%
* Last Year Same month Loss is 4.25%