

**Transmission Losses for the month of June2012 (applicable for OA users
effective from 00'hrs of 26th July12 to 24'hrs of 25th Aug12)**

		EBC Data				
		INPUT		OUTPUT		
		NET ENERGY in MU		MU		
APGENCO	TOTAL	3083.17		DISCOM	220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders	
	THERMAL	2942.38		CPDCL	2904.26	
	HYDEL	140.79		EPDCL	1029.17	
C.G.S				NPDCL	766.36	
	CGS (Injection at AP-Periphery)	1556.85		SPDCL	1532.42	
	NTPC-SIMHADRI	604.13		Total	6232.22	
APGPCL	TOTAL	108.45				
	APGPCL Stage-I	0.06				
	APGPCL Stage-II	108.39				
IPPs	TOTAL	870.71				
	GMR Bargemounted	53.41				
	GVK	157.63				
	Spectrum	89.20				
	Lanco	165.14				
	Reliance	79.96				
	VGPL	94.06				
	Gowthami	124.86				
	Konaseema	106.45				
	M.P.Ps	TOTAL	3.19			
		LVS	-0.04			
		Srivatsa	3.22			
	CPPs	TOTAL	158.48			
132KV My Home Cements - I		2.84				
132KV My Home Cements-II		0.00				
Essar Steel Ltd 132 kV Naval Warf		0.02				
HWP		7.02				
Kesoram		0.25				
NBFA # 1		42.18				
NBFA # 2		12.96				
Sitapuram Power Limited		16.39				
NCS Sugars		12.01				
Madhucon SPIL 132 kV Kusumanchi		7.56				
Sarvaraya Sugars Ltd.		1.27				
BPL 132 kV Sitharampatnam		0.00				
VSP		0.01				
Silk Road Sugars		0.00				
Empoe Power Company Ltd.,		0.00				
Penna Power Limited 132KV Ganeshpahadu#2		39.86				
Shalivahana (MSW) Green Energy Pvt. Ltd.		2.85				
VRK Sugars Ltd., 132KV Nallajerla		0.00				
Krishnaveni sugars		12.57				
132 kV Madras Cements Ltd.		0.68				
Non-Convention al (132 Kv PDs)		TOTAL	63.47			
		220KV ENERCON Wind farms	0.00			
	Agri Gold	2.23				
	G.S.R.Sugars Pvt Ltd	-0.05				
	Ganapathi Sugars Ltd.	-0.09				
	GMR Technologies Ltd.	7.84				
	Kakatiya Cement & Sugar Industries Ltd.	-0.01				
	Nagarjuna Green Power Ltd. (NGPL)	0.01				
	Sagar Sugar & Allied Products Ltd.	1.81				
	Jeypore Sugars Ltd.	-0.06				
	AP Paper Mills Ltd.	0.00				
	Nizam Deccan Sugars Ltd.	-0.12				
	Shravana Power Projects Pvt. Ltd.	3.26				
	Enercon Pvt Ltd	33.68				
	SUZLON Wind Farms	14.98				
	Others (132 Kv PDs)	TOTAL	29.78			
		R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	2.62			
		Sriba Industries Ltd.	4.05			
		Rain Calcining Ltd.	23.10			
				Losses	MU	%
			With in State	246.02	3.80	
			Total Losses	246.02	3.80	
	TOTAL INPUT	6478.24				

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.
 * MRI Data considered is from 00.00 Hr of 1st June 2012 to 24.00 Hr of 30th June2012 at 00.30 hr interval.
 * The SR Losses (External Losses to APTRANSCO) for the month of May12 is 4.69 %
 * Last Year Same month Loss is 4.15%
