

Transmission Losses for the month of Mar2012 (applicable for OA users effective from 00'hrs of 26th Apr12 to 24'hrs of 25th May12)				
EBC Data				
		INPUT	OUTPUT	
		NET		
		ENERGY		
		in MU	DISCOM	MU
APGENCO	TOTAL	3659.18	220kV/33kV,132kV/33kV,	
	THERMAL	3274.19	CPDCL	3409.73
	HYDEL	384.99	EPDCL	1141.72
C.G.S			NPDCL	1174.21
	CGS (Injection at AP-Periphery)	1863.39	SPDCL	1671.25
	NTPC-SIMHADRI	729.40	Total	7396.92
APGPCL	TOTAL	113.15		
	APGPCL Stage-I	0.17		
	APGPCL Stage-II	112.97		
IPPs	TOTAL	1099.16		
	GMR Bargemounted	69.44		
	GVK	211.45		
	Spectrum	102.10		
	Lanco	182.90		
	Reliance	108.50		
	VGPL	120.29		
	Gowthami	163.11		
	Konaseema	141.36		
M.P.Ps	TOTAL	7.51		
	LVS	-0.04		
	Srivatsa	7.55		
CPPs	TOTAL	199.50		
	Essar Steel Ltd 132 kV Naval Warf	0.19		
	HWP	8.67		
	Kesoram	0.00		
	NBFA # 1	63.72		
	NBFA # 2	13.42		
	Sitapuram Power Limited	18.87		
	NCS Sugars	8.16		
	Madhucon SPIL 132 kV Kusumanchi	14.87		
	Sarvaraya Sugars Ltd.	6.44		
	BPL 132 kV Sitharampatnam	0.00		
	VSP	0.07		
	Silk Road Sugars	0.00		
	Empee Power Company Ltd.,	4.56		
	Penna Power Limited 132KV Ganeshpahadu#2	40.16		
	Shalivahana (MSW) Green Energy Pvt. Ltd.	4.84		
	VRK Sugars Ltd., 132KV Nallajerla	0.00		
	Krishnaveni sugars	15.53		
Non-Conventional (132 Kv PDs)	TOTAL	29.76		
	Clarion Power Corporation Ltd	2.01		
	G.S.R.Sugars Pvt Ltd	0.84		
	Ganapathi Sugars Ltd.	6.68		
	GMR Technologies Ltd.	2.54		
	Kakatiya Cement & Sugar Industries Ltd.	0.46		
	Nagarjuna Green Power Ltd. (NGPL)	0.01		
	Sagar Sugar & Allied Products Ltd.	3.57		
	Jeypore Sugars Ltd.	3.12		
	AP Paper Mills Ltd.	0.00		
	Nizam Deccan Sugars Ltd.	-0.30		
	Shravana Power Projects Pvt. Ltd.	3.44		
	Enercon Pvt Ltd	7.40		
Others (132 Kv PDs)	TOTAL	35.23		
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.15		
	Sriba Industries Ltd.	5.08		
	Rain Calcining Ltd.	27.00	Losses	MU %
			With in State	339.36 4.39
			Total Losses	339.36 4.39
	TOTAL INPUT	7736.28		

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.
 * MRI Data considered is from 00.00 Hr of 1stMar 2012 to 24.00 Hr of 31st Mar2012 at 00.30 hr interval.
 * The SR Losses (External Losses to APTRANSCO) for the month of Mar12 is 5.24 %
 * Last Year Same month Loss is 4.59%