

| Transmission Losses for the month of Nov2012 (applicable for OA users effective from 00'hrs of 26th Dec12 to 24'hrs of 25th Jan13) | | | | | | |
|--|--|------------------|--|--------|---------|------|
| EBC Data | | | | | | |
| | | INPUT | | OUTPUT | | |
| | | NET ENERGY in MU | DISCOM | MU | | |
| | | | 220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders | | | |
| APGENCO | TOTAL | 2909.58 | | | | |
| | THERMAL | 2581.87 | CPDCL | | 2715.76 | |
| | HYDEL | 327.70 | EPDCL | | 938.65 | |
| C.G.S | | | NPDCL | | 822.33 | |
| | CGS (Injection at AP-Periphery) | 1840.65 | SPDCL | | 1422.75 | |
| | NTPC-SIMHADRI | 522.47 | Total | | 5899.49 | |
| APGPCL | TOTAL | 86.11 | | | | |
| | APGPCL Stage-I | 0.85 | | | | |
| | APGPCL Stage-II | 85.26 | | | | |
| IPPs | TOTAL | 493.37 | | | | |
| | GMR Bargemounted | 19.58 | | | | |
| | GVK | 102.94 | | | | |
| | Spectrum | 65.81 | | | | |
| | Lanco | 115.29 | | | | |
| | Reliance | 42.45 | | | | |
| | VGPL | 42.99 | | | | |
| | Gowthami | 54.76 | | | | |
| | Konaseema | 49.57 | | | | |
| M.P.Ps | TOTAL | 3.31 | | | | |
| | LVS | -0.03 | | | | |
| | Srivatsa | 3.34 | | | | |
| CPPs | TOTAL | 209.97 | | | | |
| | 132KV My Home Cements I & II | 20.25 | | | | |
| | Essar Steel Ltd 132 kV Naval Warf | 0.03 | | | | |
| | HWP | 6.15 | | | | |
| | Kesoram | 0.00 | | | | |
| | NBFA # 1 | 58.20 | | | | |
| | NBFA # 2 | 12.30 | | | | |
| | Sitapuram Power Limited | 19.53 | | | | |
| | NCS Sugars | 8.82 | | | | |
| | Madhucon SPIL 132 kV Kusumanchi | 12.98 | | | | |
| | Sarvaraya Sugars Ltd. | 5.74 | | | | |
| | BPL 132 kV Sitharampatnam | 0.15 | | | | |
| | VSP | 0.16 | | | | |
| | Silk Road Sugars | 0.00 | | | | |
| | Empee Power Company Ltd., | 3.43 | | | | |
| | Penna Power Limited 132KV Ganeshpahad | 34.86 | | | | |
| | Shalivahana (MSW) Green Energy Pvt. Ltd. | 4.54 | | | | |
| | VRK Sugars Ltd., 132KV Nallajerla | 0.00 | | | | |
| | Krishnaveni sugars | 13.12 | | | | |
| | 132 kV Madras Cements Ltd. | 4.09 | | | | |
| | 132KV Laxmi Tulasi | 2.83 | | | | |
| | Orient Cement 132 kV | 2.22 | | | | |
| | Steel Exchange India Ltd. 132kV | 0.57 | | | | |
| Non-Conventional (132 Kv PDs) | TOTAL | 32.50 | | | | |
| | 220KV ENERCON Wind farms | 5.54 | | | | |
| | Agri Gold | -0.03 | | | | |
| | G.S.R.Sugars Pvt Ltd | 1.12 | | | | |
| | Ganapathi Sugars Ltd. | 1.86 | | | | |
| | GMR Technologies Ltd. | 2.50 | | | | |
| | Kakatiya Cement & Sugar Industries Ltd. | 4.21 | | | | |
| | Nagarjuna Green Power Ltd. (NGPL) | 0.01 | | | | |
| | Sagar Sugar & Allied Products Ltd. | 4.13 | | | | |
| | Jeypore Sugars Ltd. | 1.05 | | | | |
| | AP Paper Mills Ltd. | 0.00 | | | | |
| | Nizam Deccan Sugars Ltd. | 0.84 | | | | |
| | Shravana Power Projects Pvt. Ltd. | 1.46 | | | | |
| | Enercon Pvt Ltd | 5.20 | | | | |
| | SUZLON Wind Farms | 4.60 | | | | |
| Others (132 Kv PDs) | TOTAL | 28.16 | | | | |
| | R.V.K. Energy Pvt. Ltd. (G.B.R. Power) | 3.69 | | | | |
| | Sriba Industries Ltd. | 3.50 | | | | |
| | Rain Calcining Ltd. | 20.97 | Losses | | MU | % |
| | | | With in State | | 226.64 | 3.70 |
| | TOTAL INPUT | 6126.13 | Total Losses | | 226.64 | 3.70 |
| * The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte. | | | | | | |
| * MRI Data considered is from 00.00 Hr of 1st Nov2012 to 24.00 Hr of 30th Nov2012 at 00.30 hr interval. | | | | | | |
| * The SR Losses (External Losses to APTRANSCO) for the month of Nov12 is 4.57% | | | | | | |
| * Last Year Same month Loss is 4.24% | | | | | | |