

**Transmission Losses for the month of Oct2012 (applicable for OA users effective from 00'hrs
of 26th Nov12 to 24'hrs of 25th Dec12)**

| | | EBC Data | | | |
|-------------------------------|--|------------------|--|--------|---------|
| | | INPUT | | OUTPUT | |
| | | NET ENERGY in MU | | | |
| | | | DISCOM | MU | |
| APGENCO | TOTAL | 3146.66 | 220kV/33kV,132kV/33kV,132/11kV Power Tr. & 220kV,132kV EHT Feeders | | |
| | THERMAL | 2749.19 | CPDCL | | 2971.78 |
| | HYDEL | 397.47 | EPDCL | | 1064.85 |
| C.G.S | | | NPDCL | | 1010.27 |
| | CGS (Injection at AP-Periphery) | 2093.94 | SPDCL | | 1507.63 |
| | NTPC-SIMHADRI | 536.03 | Total | | 6554.52 |
| APGPCL | TOTAL | 94.99 | | | |
| | APGPCL Stage-I | 12.77 | | | |
| | APGPCL Stage-II | 82.22 | | | |
| IPPs | TOTAL | 656.32 | | | |
| | GMR Bargemounted | 30.68 | | | |
| | GVK | 128.20 | | | |
| | Spectrum | 78.56 | | | |
| | Lanco | 133.04 | | | |
| | Reliance | 54.57 | | | |
| | VGPL | 75.80 | | | |
| | Gowthami | 97.82 | | | |
| | Konaseema | 57.54 | | | |
| M.P.Ps | TOTAL | 4.08 | | | |
| | LVS | 0.60 | | | |
| | Srivatsa | 3.48 | | | |
| CPPs | TOTAL | 227.33 | | | |
| | 132KV My Home Cements I & II | 21.08 | | | |
| | Essar Steel Ltd 132 kV Naval Warf | 0.01 | | | |
| | HWP | 5.81 | | | |
| | Kesoram | 0.68 | | | |
| | NBFA # 1 | 53.06 | | | |
| | NBFA # 2 | 12.71 | | | |
| | Sitapuram Power Limited | 19.44 | | | |
| | NCS Sugars | 9.73 | | | |
| | Madhucon SPIL 132 kV Kusumanchi | 16.29 | | | |
| | Sarvaraya Sugars Ltd. | 7.09 | | | |
| | BPL 132 kV Sitharampatnam | 0.06 | | | |
| | VSP | 0.06 | | | |
| | Silk Road Sugars | 0.00 | | | |
| | Empee Power Company Ltd., | 8.88 | | | |
| | Penna Power Limited 132KV Ganeshpahadu#2 | 41.51 | | | |
| | Shalivahana (MSW) Green Energy Pvt. Ltd. | 3.72 | | | |
| | VRK Sugars Ltd., 132KV Nallajerla | 0.00 | | | |
| | Krishnaveni sugars | 18.09 | | | |
| | 132 kV Madras Cements Ltd. | 1.89 | | | |
| | 132KV Laxmi Tulasi | 4.03 | | | |
| | Orient Cement 132 kv | 3.19 | | | |
| Non-Conventional (132 Kv PDs) | TOTAL | 81.57 | | | |
| | 220KV ENERCON Wind farms | 56.24 | | | |
| | Agri Gold | -0.04 | | | |
| | G.S.R.Sugars Pvt Ltd | -0.06 | | | |
| | Ganapathi Sugars Ltd. | -0.12 | | | |
| | GMR Technologies Ltd. | 0.34 | | | |
| | Kakatiya Cement & Sugar Industries Ltd. | 8.59 | | | |
| | Nagarjuna Green Power Ltd. (NGPL) | 0.01 | | | |
| | Sagar Sugar & Allied Products Ltd. | 2.20 | | | |
| | Jeyapore Sugars Ltd. | -0.01 | | | |
| | AP Paper Mills Ltd. | 0.00 | | | |
| | Nizam Deccan Sugars Ltd. | -0.12 | | | |
| | Shravana Power Projects Pvt. Ltd. | 1.01 | | | |
| | ENERCON Pvt Ltd | 9.29 | | | |
| | SUZLON Wind Farms | 4.23 | | | |
| Others (132 Kv PDs) | TOTAL | 28.76 | | | |
| | R.V.K. Energy Pvt. Ltd. (G.B.R. Power) | 4.26 | | | |
| | Sriba Industries Ltd. | 3.71 | | | |
| | Rain Calcining Ltd. | 20.79 | Losses | MU | % |
| | | | With in State | 315.15 | 4.59 |
| | TOTAL INPUT | 6869.67 | Total Losses | 315.15 | 4.59 |

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

* MRI Data considered is from 00.00 Hr of 1st Oct2012 to 24.00 Hr of 31st Oct2012 at 00.30 hr interval.

* The SR Losses (External Losses to APTRANSCO) for the month of Oct12 is 4.02%

* Last Year Same month Loss is 4.18%