

Transmission Losses for the month of Oct2013					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
APGENCO	TOTAL	3065.84	220kV/33kV,132kV/33kV,132		
	THERMAL	2391.14	CPDCL	3065.25	
	HYDEL	764.70	EPDCL	1074.31	
C.G.S			NPDCCL	945.24	
	CGS (Injection at AP-Periphery)	2439.39	SPDCL	1545.19	
	NTPC-SIMHADRI	555.04	Total	6631.00	
APGPCL	TOTAL	83.27			
	APGPCL Stage-I	0.05			
	APGPCL Stage-II	83.22			
IPPs	TOTAL	289.51			
	GMR Bargemounted	-0.17			
	GVK	75.15			
	Spectrum	70.19			
	Lanco	109.68			
	Reliance	35.83			
	VGPL	-0.63			
	Gowthami	-0.27			
	Konaseema	-0.27			
	TOTAL	3.30			
	LVS	-0.03			
Srivatsa	3.33				
CPPs	TOTAL	346.87			
	132KV My Home Cements I & II	13.20			
	Essar Steel Ltd 132 kV Naval Warf	0.09			
	HWP	5.02			
	Kesoram	0.23			
	NBFA # 1 & #2	50.18			
	Navabharath Ventures Ltd Prathipadu	11.26			
	Sitapuram Power Limited	15.36			
	NCS Sugars	0.00			
	Madhucon SPIL 132 kV Kusumanchi	14.25			
	Sarvaraya Sugars Ltd.	5.64			
	BPL 132 kV Sitharampatnam	0.01			
	VSP	0.00			
	Silk Road Sugars	0.00			
	Empire Power Company Ltd.	0.00			
	Perina Power Limited 132KV Ganeshpahadu#2	23.72			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	2.16			
	VRK Sugars Ltd., 132KV Nalajerla	0.00			
	Krishnaveni sugars	14.81			
	132 kV Madras Cements Ltd.	0.08			
	132KV Laxmi Tulasi	2.56			
	Orient Cement 132 kV	1.07			
	Steel Exchange India Ltd. 132kV	19.73			
	Sarda Metals & Alloys Ltd	45.42			
	NBEIL #1	42.94			
	NBEIL #2	42.55			
	Anrak Aluminium Ltd.	1.68			
	Jaypee Cements	0.04			
	BMM Cements	7.51			
	SBQ Steels	16.08			
	Hetro Wind Power	6.92			
	ICL (Rassi Cements)	0.00			
	Girija Alloy Power Ltd	4.38			
PSR Green Power Proj. Pvt. Ltd.	0.00				
Non-Conventional (132 Kv PDs)	TOTAL	37.93			
	220KV ENERCON Wind farms	10.59			
	Agri Gold	-0.02			
	G.S.R. Sugars Pvt Ltd	-0.07			
	Ganapathi Sugars Ltd.	-0.10			
	GMR Technologies Ltd.	-0.41			
	Kakatiya Cement & Sugar Industries Ltd.	-0.12			
	Nagarjuna Green Power Ltd. (NGPL)	0.01			
	SNU Sugars & Products Ltd	-0.04			
	Jaypore Sugars Ltd.	-0.01			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	-0.05			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Enercon Pvt Ltd	8.45			
	SUZLON Wind Farms (Ragulapadu)	8.85			
	SUZLON Wind Farms JMDG-I	3.25			
	SUZLON Wind Farms JMDG-II	3.35			
	RCI Pooling station -Kadavakallu	4.28			
	Tayata Wind farms Feeder	0.00			
	Others (132 Kv PDs)	TOTAL	24.40		
R.V.K. Energy Pvt. Ltd. (G.B.R. Power)		4.17			
Sriba Industries Ltd.		2.28			
Rain Calcining Ltd.		17.95	Losses	MU	%
			With in State	214.54	3.13
	TOTAL INPUT	6845.54	Total Losses	214.54	3.13

*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Nov 2013 to 24.00'hours of 25th Dec 2013
* The Transmission Losses are worked out using MIRI data.
* MIRI Data considered is from 00.00 hr of 1st Oct 2013 to 24.00 Hr of 31st Oct 2013 at 00.30 hr interval.
* The SR Losses (External Losses to APTRANSCO) for the month of Oct 13 is 3.26%
* Last Year Same month Loss is 4.59%