

Transmission Losses for the month of Sep2012 (applicable for OA users effective from 00'hrs of 26th Oct12 to 24'hrs of 25th Nov12)						
EBC Data						
		INPUT		OUTPUT		
		NET ENERGY in MU		DISCOM	MU	
APGENCO	TOTAL	3176.67		220kV/33kV,132kV/33kV		
	THERMAL	2664.39		CPDCL	2841.23	
	HYDEL	512.28		EPDCL	964.77	
C.G.S				NPDCL	915.15	
	CGS (Injection at AP-Periphery)	1938.44		SPDCL	1434.26	
	NTPC-SIMHADRI	351.83		Total	6155.41	
APGPCL	TOTAL	79.26				
	APGPCL Stage-I	0.08				
	APGPCL Stage-II	79.18				
IPPs	TOTAL	573.84				
	GMR Bargemounted	26.26				
	GVK	115.52				
	Spectrum	79.00				
	Lanco	112.10				
	Reliance	44.09				
	VGPL	66.06				
	Gowthami	60.38				
	Konaseema	70.43				
M.P.Ps	TOTAL	3.64				
	LVS	0.00				
	Srivatsa	3.64				
CPPs	TOTAL	196.36				
	132KV My Home Cements I & II	14.13				
	Essar Steel Ltd 132 kV Naval Warf	0.02				
	HWP	5.89				
	Kesoram	1.25				
	NBFA # 1	44.28				
	NBFA # 2	12.85				
	Sitapuram Power Limited	18.18				
	NCS Sugars	9.10				
	Madhucon SPIL 132 kV Kusumanchi	12.23				
	Sarvaraya Sugars Ltd.	7.45				
	BPL 132 kV Sitharampatnam	0.01				
	VSP	0.00				
	Silk Road Sugars	0.00				
	Empee Power Company Ltd.,	7.58				
	Penna Power Limited 132KV Ganeshpahu#2	38.59				
	Shalivahana (MSW) Green Energy Pvt. Ltd.	3.61				
	VRK Sugars Ltd., 132KV Nallajerla	0.00				
	Krishnaveni sugars	16.62				
	132 kV Madras Cements Ltd.	0.01				
	132KV Laxmi Tulasi	4.56				
Non-Conventional (132 Kv PDs)	TOTAL	39.45				
	220KV ENERCON Wind farms	0.00				
	Agri Gold	0.79				
	G.S.R.Sugars Pvt Ltd	-0.05				
	Ganapathi Sugars Ltd.	0.00				
	GMR Technologies Ltd.	-0.51				
	Kakatiya Cement & Sugar Industries Ltd.	7.25				
	Nagarjuna Green Power Ltd. (NGPL)	0.01				
	Sagar Sugar & Allied Products Ltd.	-0.26				
	Jeypore Sugars Ltd.	-0.04				
	AP Paper Mills Ltd.	0.00				
	Nizam Deccan Sugars Ltd.	-0.13				
	Shravana Power Projects Pvt. Ltd.	2.71				
	Enercon Pvt Ltd	19.78				
	SUZLON Wind Farms	9.90				
Others (132 Kv PDs)	TOTAL	23.19				
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	3.19				
	Sriba Industries Ltd.	3.66				
	Rain Calcining Ltd.	16.34		Losses	MU	%
				With in State	227.27	3.56
	TOTAL INPUT	6382.68		Total Losses	227.27	3.56

* The Transmission Losses are worked out using MRI data based on methodology given by M/s. Deloitte.

* MRI Data considered is from 00.00 Hr of 1st Sep2012 to 24.00 Hr of 30th Sep2012 at 00.30 hr interval.

* The SR Losses (External Losses to APTRANSCO) for the month of Sep12 is 3.59%

* Last Year Same month Loss is 4.29%