

Transmission Losses for the month of Sep2013					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
APGENCO	TOTAL	3629.94	220kV/33kV,132kV/33k		
	THERMAL	2383.84	CPDCL	3133.44	
	HYDEL	1246.10	EPDCL	1195.99	
C.G.S			NPDCL	1145.89	
	CGS (Injection at AP-Periphery)	2277.51	SPDCL	1612.30	
	NTPC-SIMHADRI	611.27	Total	7087.62	
APGPCL	TOTAL	81.12			
	APGPCL Stage-I	0.05			
	APGPCL Stage-II	81.08			
IPPs	TOTAL	276.91			
	GMR Bargemounted	-0.20			
	GVK	65.03			
	Spectrum	70.53			
	Lanco	108.66			
	Reliance	34.11			
	VGPL	-0.61			
	Gowthami	-0.34			
	Konaseema	-0.28			
M.P.Ps	TOTAL	3.12			
	LVS	-0.03			
	Srivatsa	3.16			
CPPs	TOTAL	371.93			
	132KV My Home Cements I & II	21.46			
	Essar Steel Ltd 132 kV Naval Warf	0.09			
	HWP	5.16			
	Kesoram	0.30			
	NBFA # 1 & #2	43.74			
	Navabharath Ventures Ltd Prathipadu	10.56			
	Sitapuram Power Limited	15.55			
	NCS Sugars	0.00			
	Madhucon SPIL 132 kV Kusumanchi	13.18			
	Sarvaraya Sugars Ltd.	6.19			
	BPL 132 kV Sitharampatnam	0.00			
	VSP	0.00			
	Silk Road Sugars	0.12			
	Empee Power Company Ltd.,	2.03			
	Penna Power Limited 132KV Ganeshpahadu#2	33.17			
	Shalivahana (MSW) Green Energy Pvt. Ltd.	3.01			
	VRK Sugars Ltd., 132KV Nallajerla	0.00			
	Krishnaveni sugars	13.75			
	132 kV Madras Cements Ltd.	0.06			
	132KV Laxmi Tulasi	5.85			
	Orient Cement 132 kV	0.16			
	Steel Exchange India Ltd. 132kV	21.29			
	Sarda Metals & Alloys Ltd	40.75			
	NBEIL #1	38.63			
	NBEIL #2	38.55			
	Anrak Aliminium Ltd.	21.36			
	Jaypee Cements	0.00			
	BMM Cements	6.22			
	SBQ Steels	12.37			
	Hetro Wind Power	10.58			
	ICL (Rassi Cements)	0.00			
	Girija Alloy Power Ltd	7.77			
Non-Convention al (132 Kv PDs)	TOTAL	71.89			
	220KV ENERCON Wind farms	15.57			
	Agri Gold	-0.02			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.09			
	GMR Technologies Ltd.	0.33			
	Kakatiya Cement & Sugar Industries Ltd.	6.79			
	Nagarjuna Green Power Ltd. (NGPL)	0.01			
	Sagar Sugar & Allied Products Ltd.	-0.38			
	Jeypore Sugars Ltd.	0.00			
	AP Paper Mills Ltd.	0.00			
	Nizam Deccan Sugars Ltd.	3.96			
	Shravana Power Projects Pvt. Ltd.	1.10			
	Enercon Pvt Ltd	13.85			
	SUZLON Wind Farms (Ragulapadu)	13.77			
	SUZLON Wind Farms JMDG-I	5.62			
	SUZLON Wind Farms JMDG-II	5.76			
	RCI Pooling station -Kadavakallu	5.68			
Others (132 Kv PDs)	TOTAL	15.87			
	R.V.K. Energy Pvt. Ltd. (G.B.R. Power)	4.12			
	Sriba Industries Ltd.	2.30			
	Rain Calcining Ltd.	9.45	Losses	MU	%
			With in State	251.95	3.43
	TOTAL INPUT	7339.57	Total Losses	251.95	3.43
*Transmission Losses are applicable to OA Users for the period from 00.00'hours of 26th Oct 2013 to					
* The Transmission Losses are worked out using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st Sep 2013 to 24.00 Hr of 30th Sep 2013 at 00.30 hr interval.					
* The SR Losses (External Losses to APTRANSCO) for the month of Sep 13 is 3.67 %					