


MOUNTING DETAIL

S.No.	DESCRIPTION	QTY	MATL
1	H.T TERMINAL		NICKLE PLATED COPPER
2	OIL LEVEL INDICATOR	1	AL./BRASS
3	OIL EXPANSION CHAMBER	1	M.S
4	BUSHING FLANGE (CEMENTED)	2	GI/CI
5	BUSHING	1	PORCELAIN
6	LIFTING LUG	4	M.S
7	NAME AND RATING PLATE	1	AL. Anodised
8	TANK WITH COVER	1	M.S
9	OIL DRAIN PLUG	1	M.S
10	EARTHING FLAT 80x50x8 Thick.	2	M.S
11	SECONDARY & EARTHING TERMINAL BOX	1	M.S
12	DOME	1	M.S/AL.
13	OIL FILLING PORT	1	M.S
14	BELLOW	1	S.S
15	BUSHING FLAT GASKET	2	N.B.R

NOTES :

1. ALL FERROUS PARTS EXPOSED TO THE ATMOSPHERE SHALL BE PAINTED WITH P.U PAINT SHADE 631 OF IS: 5.
2. MAKE OF BUSHING: IEC/MODERN/BHEL/ABIL/CJI
3. TOTAL CREEPAGE DISTANCE :- 6125 mm (MIN)
4. QUANTITY OF OIL :-250 LITRES APPROX.
5. TOTAL WEIGHT OF PT : 1000 KGS APPROX.
6. ALL HARDWARE SHALL BE HOT DIP GALVANIZED.
7. TRANSFORMER OIL AS PER IEC : 60296.
8. ALL GASKETS SHALL BE FIXED IN PROPERLY MACHINED GROOVES.
9. ALL GASKETS SHALL BE MADE OF NITRILE BUTYL RUBBER.

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.



Chief Engineer
Power Systems, Planning & Design
APTransco

RO	FOR APPROVAL	06.01.2021
REV.	REVISION DESCRIPTION	DATED INITIALS

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED				<div style="border: 1px solid black; padding: 2px; display: inline-block;">MEHRU</div> MEHRU ELECTRICAL & MECHANICAL ENGINEERS (P) LTD.
PROJECT NAME : AS APPLICABLE				
UNLESS OTHERWISE SPECIFIED	DATE	NAME	MATERIAL	
1. ALL DIMENSIONS ARE IN mm.	DGN. 06.01.2021	SPS	AS ABOVE	
2. TOLERANCE WHEREVER NOT INDICATED ±5%	DRN. 06.01.2021	AKASH		
	CHD. 06.01.2021	BLS		
SCALE:	N.T.S			
TITLE :				
GENERAL ARRANGEMENT DRAWING FOR 220kV INDUCTION VOLTAGE TRANSFORMER				
SHEET No. 1 OF 7				DRG.NO ME-220IVT-GA-01

4613556/2021/EEMRT-ENE51

MEHRU**INDUCTION VOLTAGE TRANSFORMER**

SR.No.	<input type="text"/>	REF.STD.	IS: 16227
TYPE	Outdoor Oil Cooled	RATIO	220 kV / $\sqrt{3}$
Highest System Voltage	245 kV		110V/ $\sqrt{3}$ - 110V/ $\sqrt{3}$
PHASE	Single	BURDEN	150 VA - 50 VA
Insulation level	460/1050 kV	CLASS	0.2 - 3P
Thermal Burden	200 VA	Simultaneous Burden	150 VA - 50 VA
Frequency	50 Hz	Type	Earthed
Voltage Factor	1.2	TIME CONT. &	1.5
		TIME FOR	30 Sec
		YEAR OF MFG.	2021


* QUANTITY OF OIL 250 LTRS. APPROX.

* TOTAL WEIGHT 1000 Kgs. APPROX. * TOTAL CREEPAGE DISTANCE 6125 mm (Minimum)

MADE IN INDIA BY

MEHRU ELECTRICAL AND MECHANICAL ENGINEERS (P) LTD.

SP-2/180, RIICO INDUSTRIAL AREA KHARANI EXT. BHIWADI-301019, RAJ. (INDIA)

SUITABLE FOR HOT LINE WASHINGCONNECTION DIAGRAM**CAUTION :**

- KEEP OPEN ALL SECONDARIES TERMINALS ARE NOT IN USE.
- ALWAYS KEEP NEUTRAL TERMINAL 'N' AND TAN DELTA TESTING TERMINAL 'C' SHORTED TO EARTH DURING OPERATION
- DO NOT REMOVE EARTH LINK WHEN IN OPERATION.

115 ±10

195 ±15

NOTES:-

- THICKNESS OF RATING PLATE 1.2 mm
- MATERIAL OF NAME PLATE SHALL BE AL. ANODIZED.
- SERIAL NUMBER SHALL BE ENGRAVING BEFORE THE DISPATCH.

Chief Engineer
Power Systems, Planning & Design
APTransco

R0	FOR APPROVAL	06.01.2021
REV.	REVISION DESCRIPTION	DATED INITIALS

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED
PROJECT NAME : AS APPLICABLE

UNLESS OTHERWISE SPECIFIED	DATE	NAME	MATERIAL
1. ALL DIMENSIONS ARE IN mm. 2. TOLERANCE WHEREVER NOT INDICATED ±5%	DGN.	06.01.2021	SPS
	DRN.	06.01.2021	AKASH
	CHD.	06.01.2021	BLS
SCALE:	N.T.S		


AL.ANODIZED

MEHRU

MEHRU ELECTRICAL &
MECHANICAL
ENGINEERS (P) LTD.

TITLE :



NAME PLATE DRAWING FOR
220kV INDUCTION VOLTAGE
TRANSFORMER



DRG.NO
ME-220IVT-NP-01

SHEET No.
3 OF 7

4613556/2021/EEMRT-ENE51




Drawing approval subject to valid vendor registration

NOTES :

1. ALL FERROUS PARTS EXPOSED TO THE ATMOSPHERE SHALL BE PAINTED WITH P.U PAINT SHADE 631 OF IS: 5.
2. MAKE OF BUSHING: IEC/MODERN/BHEL/ABIL/CJI
3. TOTAL CREEPAGE DISTANCE :- 6125 mm (MIN)
4. QUANTITY OF OIL :-250 LITRES APPROX.
5. TOTAL WEIGHT OF PT : 1000 KGS APPROX.
6. ALL HARDWARE SHALL BE HOT DIP GALVANIZED.
7. TRANSFORMER OIL AS PER IEC : 60296.
8. ALL GASKETS SHALL BE FIXED IN PROPERLY MACHINED GROOVES.
9. ALL GASKETS SHALL BE MADE OF NITRILE BUTYL RUBBER.

S.No.	DESCRIPTION	QTY	MATL
1	H.T TERMINAL	1	NICKLE PLATED COPPER
2	OIL LEVEL INDICATOR	1	AL./BRASS
3	OIL EXPANSION CHAMBER	1	M.S
4	BUSHING FLANGE (CEMENTED)	2	GI/CI
5	BUSHING	1	PORCELAIN
6	LIFTING LUG	4	M.S
7	NAME AND RATING PLATE	1	AL.Anodised
8	TANK WITH COVER	1	M.S
9	OIL DRAIN PLUG	1	M.S
10	EARTHING FLAT 80x50x8 Thick.	2	M.S
11	SECONDARY & EARTHING TERMINAL BOX	1	M.S
12	BUSHING FLAT GASKET	2	N.B.R
13	OIL FILLING PORT	1	M.S
14	BELLOW	1	S.S
15	STACK LAMINATION		CRGO
16	HT COIL WITH PAPER INSULATION	1	COPPER
17	LT COIL WITH PAPER INSULATION	1	COPPER
18	DOME	1	M.S/AL.


4613556/2021/EEMRT-ENE51




Chief Engineer
Power Systems, Planning & Design
APTransco

RO	FOR APPROVAL	06.01.2021
REV.	REVISION DESCRIPTION	DATED INITIALS

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED				PROJECT NAME : AS APPLICABLE	
UNLESS OTHERWISE SPECIFIED	DATE	NAME	MATERIAL	MEHRU MEHRU ELECTRICAL & MECHANICAL ENGINEERS (P) LTD.	
1. ALL DIMENSIONS ARE IN mm.	DGN. 06.01.2021	SPS	AS ABOVE		
2. TOLERANCE WHEREVER NOT INDICATED ±5%	DRN. 06.01.2021	AKASH			
	CHD. 06.01.2021	BLS			
	SCALE:	N.T.S		 DRG.NO ME-220IVT-SE-01	
TITLE :					
SECTIONAL ARRANGEMENT DRAWING FOR 220kV INDUCTION VOLTAGE TRANSFORMER					
SHEET No. 2 OF 7					



FRONT VIEW




SIDE VIEW


'N': NEUTRAL TERMINAL
 'C': TAN DELTA TESTING TERMINAL
 F1 & F2: FUSE 6AMP.

NOTES:-

1. SECONDARY TERMINAL BOX SHALL BE PROVIDED REMOVABLE GLAND PLATE WITHOUT HOLE.
2. SECONDARY TERMINAL BOX SHALL BE PROVIDED WITH COVER.
3. M.S SHEET THICKNESS FOR TERMINAL BOX 3.0mm. & FOR COVER 2.0mm.
4. MATERIAL OF GASKET: NITRILE BUTYL RUBBER GASKET.
5. DEGREE OF PROTECTION : IP 55
6. 20% SPARE TERMINAL SHALL BE PROVIDED.



TOP



FRONT

SIDE


MATERIAL: POLYAMIDE
 MAKE: ELMEX/CONNECTWELL

TERMINAL (DETAIL)

Drawing approval subject to valid vendor registration

Chief Engineer
 Power Systems, Planning & Design
 APTransco

4613556/2021/EEMRT-ENE51

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED				MEHRU
PROJECT NAME : AS APPLICABLE				
UNLESS OTHERWISE SPECIFIED	DATE	NAME	MATERIAL	
1. ALL DIMENSIONS ARE IN mm.	DGN. 06.01.2021	SPS	M.S	
2. TOLERANCE WHEREVER NOT INDICATED ±5%	DRN. 06.01.2021	AKASH		
	CHD. 06.01.2021	BLS		
	SCALE: N.T.S			
TITLE :				MEHRU ELECTRICAL & MECHANICAL ENGINEERS (P) LTD.
SECONDARY TERMINAL BOX DRAWING FOR 220KV INDUCTION VOLTAGE TRANSFORMER				
SHEET No. 4 OF 7				 DRG.NO ME-220IVT-STB-01

REV.	FOR APPROVAL	06.01.2021
	REVISION DESCRIPTION	DATED INITIALS

GUARANTEE TECHNICAL PARTICULAR 220kV INDUCTIVE VOLTAGE TRANSFORMER		
S. NO	DESCRIPTION	245 kv
1	Type	Mehru Electrical & Mechanical Engineers (P) Ltd, Bhiwadi, (Raj), India
2	Manufacturer's type designation	Outdoor, Oil Cooled, Electromagnetic Type, Inductive Voltage Transformer
3	Mounting of tank (bottom)	Bottom
4	System rated voltage/highest voltage (kv)	220/245
5	Rated primary voltage (kv)	220 kV/√3
6	Secondary winding details	
	(a)No.ofsecondary windings	2
	(b)Rated secondary voltage(V)	110V/√3 - 110V/√3
	(c)Rated burden VA (simultaneous)	150 VA 50 VA
	(d)Class of accuracy	Wdg:1, 0.2, Wdg 2: 3P
7	Maximum ratio error with % rated burden and 5 % normal primary voltage	In limits as per IS 16227
8	Maximum phase angle error with % rated burden and 5 % normal primary voltage	In limits as per IS 16227
9	Temperature rise at 1.1 times rated voltage with rated burden deg.C	50deg C
10	Rated voltage factor and time	1.2 continuous & 1.5 for 30 seconds
11	Temperature rise for item-10 above deg.C	Within limit as per IS 16227
12	Impulse withstand test voltage (kv) peak	1050
13	One minute power frequency withstand test voltage on secondary (kv rms)	3
14	One minute power frequency withstand test voltage on primary (kv rms)	460
15	Total creepage distance of the bushing mm	25 mm/kV i.e. 6125 mm
16	Grade of oil	EHV IS 335/IEC 60296
17	Quantity of insulating oil (Litres)	250 Ltr Approx
18	Weight of oil (kg)	200 kgs Approx
19	Total weight including oil (kg)	1000KG Approx
20	Whether sealed (if so type of sealing)	Yes, SS BELLOW
21	Over all dimensions	
	Height (mm)	3950±75 mm
	Length (mm)	450±5 mm
	Breadth (mm)	450±5 mm
22	Weight of Steel	160 kgs (Approx.)
	Wight of Aluminum	15 kgs (Approx.)
	Weight of copper	15 kgs (Approx.)
a)	Radio interference voltage	As per IS 16227 Clause 6.11.2 <2500uV
b)	Partial discharge level	<10 pC at Um & <5 pc at 1.2Um/√3
	Tan delta	<0.005

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.

Since the supply of terminal connectors is not in the scope of manufacturer as mentioned in the drawings, the EPC contractors shall be instructed to supply the same in line with CT/IVT/CVT requirement and compatibility.

FOR EPC CONTRACTS ONLY

Chief Engineer
Power Systems, Planning & Design
APTransco