


NOTE: 1. Drawings approval subject to valid type test reports, to be checked during acceptance tests.

2. For EPC contractors only.

		Customer : Transmission corporation of Andhra Pradesh Limited (APTransco)	
		PROJECTNAME:- AS APPLICABLE	
		PO:-	
		Contractor:- AS APPLICABLE	
		TITLE: Power Cable	
SR. NO.	PARTICULARS	Unit	3.5 C X 35
	Description		Confirmation/Commitment by the Supplier/Bidder
1	Name of Manufacturer.		CHANDRESH CABLES LTD(BRAND NAME-AVOCAB)
2	Applicable Standard.		IS : 1554 (PART-1) 1988
3	Voltage Grade.	Volts	1100
4	Permission variation in a)Voltage	%	±10
	b)Frequency	%	±5
	c) Combined	%	±10
5	Wheather Suitable for Earthed or Uearthed System		Both
6	SIZE	SQ.MM	3.5 C X 35
7	Type. Drawing approval subject to valid vendor registration		AYFY (FRLS & C2 TYPE)
8	Conductor :		
a.	Material		H2 GRADE ALUMINIUM AS PER IS 8130 : 2013
b.	Nominal Size (Phase / Neutral)	SQ.MM	35 / 16
c.	Number of wires in each conductor (Phase/Neutral)	Nos.	7/7
d.	Diameter of Each Wire (Phase/Neutral) (Before Stranding) Minimum	mm	2.53 / 1.71
e.	Shape of conductor		STRANDED SECTOR SHAPE
f.	Direction of lay of Conductor		RIGHT HAND LAY
g.	DC Resistance at 20°C (MAX.) PHASE/NEUTRAL	Ohms/Km	0.868 / 1.91
h.	AC Resistance at 90°C (MAX.) PHASE/NEUTRAL	Ohms/Km	1.11 / 2.44
9	Insulation		
a.	Material.		EXTRUDED PVC TYPE A
b.	IS Reference		IS :1554 (PART-1) 1988
c.	Nominal Thickness. (Phase / Neutral)	mm	1.2 / 1.0
d.	Cores identification		RED , YELLOW , BLUE & BLACK
f.	Cores identification		Confirming to : IS 1554
10	Inner Sheath		
a.	Material.		EXTRUDED PVC TYPE ST-1
b.	IS Reference		IS : 5831 - 1984
c.	Minimum Thickness	mm	0.3
d.	Mimimum Fictitious Diameter over Inner Sheath	mm	21.049
e.	Colour of inner sheath		Black

CHIEF ENGINEER/PROJECTS
APTRANSCO/VIS/VIJAYAWADA


acceptance tests.

2.For EPC contractors only.

11	Armouring		
a.	Material & Type		GALVANIZED STEEL STRIP
b.	Extruded OR Wrapped		Wrapped
c.	IS Reference		IS: 3975/1999
d.	Nominal Diameter	mm	4 X 0.80
e.	Mimimum Fictitious Diameter over Armour	mm	22.649
f.	Direction of lay of armour		LEFT HAND LAY
g.	DC Resistance of armour (Max)	ohm/km	As per IS:1554(P-1)1988 Table No-6
12	Outer Sheath		
a.	Material.		EXTRUDED PVC
b.	Type.	CHIEF ENGINEER/PROJECTS	ST-2 WITH FRLS PROPERTY
c.	IS Reference	APTRANSCO/VS/VIJAYAWADA	IS : 5831 - 1984
d.	Minimum Thickness	mm	1.40
e.	Colour		BLACK
f.	Mimimum Fictitious Diameter of Cable	mm	25.449
13	FRLS PROPERTIES		
a.	Oxygen Index Minimum	%	29
b.	Temperature index Minimum	Deg C	250
c.	Smoke Density Maximum	%	60
d.	Acid Gas Generation (HCL%)Maximum	%	20
e.	Flamibility Test a.Unefected Portion (min.)	mm	50
	b. Flame Duration (Max.)	sec.	60
14	Insulation Test		
	a) Minimum volume resistivity at (ohm-cm)		
	(i) 27 deg. C.		1×10^{13}
	(ii) 70 deg. C.		1×10^{10}
15	(i) Minimum tensile - strength of insulation	N/mm ²	12.5(min)as per IS 5831:1984
	(ii) Minimum elongation at break	%	150(min)as per IS 5831:1984
16	(i) Minimum tensile - strength of sheath	N/mm ²	12.5(min)as per IS 5831:1984
	(ii) Minimum elongation at break	%	150(min)as per IS 5831:1984
17	(i) Minimum tensile - strength of armour	Mpa	300-500 as per IS 3975:1999
	(ii) Minimum elongation at break	%	10(min) as per IS 3975:1999
18	PVC Cable		
	a) High voltage test		3KV(rms) for 5mint as per IS 1554(part-1):1988
	c) Short circuit current rating for armour		KA/Vt (K-0.05 Amp) (where A = Area of Armour in mm ² & t = time in seconds)

NOTE: 1. Drawings Approval subject to valid type test reports, to be checked during acceptance tests.

2.For EPC contractors only.

19	a)Current carrying capacity in air and corresponding assumptions/conditions of installation		As per IS: 1255
20	ELECTRICAL CHARACTERISTICS		
a.	laying up of cable is accordance with		Confirming to IS:3961-2
b.	Continuous Current Rating for Standard IS Condition when Laid.		
	i. In Ground.at 30°C	Amps	As per IS:3961-2
	ii. In Air at 40°C		
	iii. In Air at 50°C	Amps	
e.	Short Circuit Rating for 1 Sec. Duration	KA	2.61
f.	Wheather Suitable for Earthed or Uearthed System		70
g.	Conductor Temperature allowed for the short circuit condition (Max.)	°C	160
22	GENERAL		
a.	Standard drum length	Mts	500/1000 (±5 %)
b.	Cable - Drum		Shall confirm to IS 10418 only
c.	Recommended min. Bending radius of cable	mm	12 X OVERALL DIA OF A CABLE
d.	Recommended Max. Safe pulling force		
	i) When Cable Pulled by pulling eye	N	3675
e.	Packing Material		NON RETURNABLE WOODEN DRUM
f.	Embossing on Cable		PROVIDE AS PER IS-1554 (PART-1)1988, Name of Customer, Year of manufacturing, FRLS,APTRANSCO
g.	Cable should be ISI Marked		Yes , All cable furnish with ISI - Marked only
h.	Sequential marking of length (Printing)		PROVIDE EVERY METER
i	End cap		Provided both end of cable
			

Drawing approval subject to valid vendor registration

**CHIEF ENGINEER/PROJECTS
APTRANSCO/VIS/VIJAYAWADA**