


NOTE: 1. Drawings APPROVAL subject to valid type test reports, to be checked during acceptance tests.
 2.For EPC contractors only.

		Customer : Transmission corporation of Andhra Pradesh Limited (APTransco)	
		PROJECTNAME:- AS APPLICABLE	
		PO :-	
		Contractor:-AS APPLICABLE	
		TITLE: Power Cable	
PARTICULARS		4 C X 16	
SR. NO.	Description	Unit	Confirmation/Commitment by the Supplier/Bidder
1	Name of Manufacturer. Drawing approval subject to valid vendor registration		CHANDRESH CABLES LTD(BRAND NAME-AVOCAB)
2	Applicable Standard.		IS :1554 (PART-1) 1988
3	Voltage Grade.	Volts	1100
4	Permission variation in a)Voltage	%	±10
	b)Frequency	%	±5
	c) Combined	%	±10
5	Wheather Suitable for Earthed or Uearthed System		Both
6	SIZE	SQ.MM	4 C X 16
7	Type.		AYFY (FRLS & C2 TYPE)
8	Conductor :		
a.	Material		H2 GRADE ALUMINIUM AS PER IS 8130 : 2013
b.	Nominal Size (Phase / Neutral)	SQ.MM	16
c.	Number of wires in each conductor (Phase / Neutral)	Nos.	7
d.	Diameter of Each Wire (Phase/Neutral) (Before Stranding) Minimum	mm	1.71
e.	Direction of lay of conductor		RIGHT HAND LAY
f.	Shape of conductor		STRANDED SECTOR SHAPED
g.	DC Resistance at 20°C (MAX.) PHASE/NEUTRAL	Ohms/Km	1.91
h.	AC Resistance at 90°C (MAX.) PHASE/NEUTRAL	Ohms/Km	2.44
9	Insulation		
a.	Material.		EXTRUDEDPVC TYPE A
b.	IS Reference		IS : 1554(PART-1) 1988
c.	Nominal Thickness. (Phase / Neutral)	mm	1.00
d.	Cores identification		RED,YELLOW,BLUE & BLACK (As per IS:1554-1/1988)
10	Inner Sheath		
a.	Material.		EXTRUDED PVC TYPE ST-1
b.	IS Reference		IS : 5831 - 1984
c.	Minimum Thickness	mm	0.30
d.	Mimimum Fictitious Diameter over Inner Sheath	mm	16.33
e.	Colour of inner sheath		Black

CHIEF ENGINEER/PROJECTS
APTRANSCO/VISVIJAYAWADA

acceptance tests.

2.For EPC contractors only.

11	Armouring		
a.	Material & Type		GALVANIZED STEEL FLAT STRIP
b.	Extruded OR Wrapped		Wrapped
c.	IS Reference		IS: 3975/1999
d.	Nominal Diameter	mm	4 X 0.80
e.	Mimimum Fictitious Diameter over Armour	mm	17.93
f.	Direction of lay of armour		LEFT HAND LAY
h.	DC Resistance of armour (Max)	ohm/km	As per IS:1554(P-1)1988 Table no-6
12	Outer Sheath		
a.	Material.		EXTRUDED PVC
b.	Type.		ST-2 WITH FRLS PROPERTY
c.	IS Reference	CHIEF ENGINEER/PROJECTS	IS : 5831 - 1984
d.	Minimum Thickness	APTRANSCO/VIS/VIJAYAWADA	mm 1.40
e.	Colour		BLACK
g.	Mimimum Fictitious Diameter of Cable	mm	20.73
13	FRLS PROPERTIES		
a.	Oxygen Index Minimum	%	29
b.	Temperature index Minimum	Deg C	250
c.	Smoke Density Maximum	%	60
d.	Acid Gas Generation (HCL%) Maximum	%	20
e.	Flamibility Test a.Unefected Portion (min.)	mm	50
	b. Flame Duration (Max.)	sec.	60
14	Insulation Test		
	Minimum volume resistivity at (ohm-cm)		
	(i) 27 deg. C.		1 X 10 ¹³
	(ii) 70 deg. C.		1 X 10 ¹⁰
15	(i)Minimum tensile - strength of insulation	N/mm ²	12.5(min)as per IS 5831:1984
	(ii)Minimum elongation at break	%	150(min)as per IS 5831:1984
16	(i)Minimum tensile - strength of sheath	N/mm ²	12.5(min)as per IS 5831:1984
	(ii)Minimum elongation at break	%	150(min)as per IS 5831:1984
17	(i)Minimum tensile - strength of armour	Mpa	300-500 as per IS 3975:1999
	(ii)Minimum elongation at break	%	10(min) as per IS 3975:1999
18	PVC Cable		
	a) High voltage test		3KV(rms) for 5mint as per IS 1554(part-1):1988
	b) Short circuit current rating for armour	KA	KA/Vt (K-0.05 Factor in Amp) (where A = Area of Armour in mm2& t = time in seconds)

NOTE: 1. Drawings Approval subject to valid type test reports, to be checked during acceptance tests.

2.For EPC contractors only.

19	Current carrying capacity in air and corresponding assumptions/conditions of installation		As per IS : 1255
20	ELECTRICAL CHARACTERISTICS		
a.	laying up of cable is accordance with		Confirming to IS:3961-2
b.	Continuous Current Rating for Standard IS Condition when Laid.		
i.	In Ground.at 30°C	Amps	As per IS:3961-2
ii.	In Air at 40°C	Amps	
iii.	In Air at 50°C	Amps	
c.	Short Circuit Rating for 1 Sec. Duration	KA	1.19 KA
d.	Conductor Temperature allowed for Continuous Operation condition (Max.)		70
e.	Conductor Temperature allowed for the short circuit condition (Max.)	°C	160
21	GENERAL		
a.	Standard drum length	Mts	500/1000 (±5 %)
b.	Cable - Drum		Shall confirm to IS 10418 only
c.	Recommended min. Bending radius of cable	mm	12 X OVERALL DIA OF A CABLE
d.	Recommended Max. Safe pulling force		
i)	When Cable Pulled by pulling eye	N	1920
e.	Packing Material		NON RETURNABLE WOODEN DRUM
f.	Embossing on Cable		PROVIDE AS PER IS-1554 (PART-1)1988, Name of Customer, Year of manufacturing, FRLS , APTRANSCO
g.	Cable should be ISI Marked		Yes , All cable furnish with ISI - Marked only
h.	Sequential marking of length (Printing)		PROVIDE EVERY METER
i	End cap		Provided both end of cable
<p>CHIEF ENGINEER/PROJECTS APTRANSCO/VIS/VIJAYAWADA</p>			



Drawing approval subject to valid vendor registration