

# 245 KV CURRENT TRANSFORMER TYPE: IMB 245

CLIENT:  
(AS APPLICABLE)

END CUSTOMER:  
APTRANSCO

W.O. NO.:  
(AS APPLICABLE)

Drawing approval subject to valid vendor registration

PROJECT:  
(AS APPLICABLE)

P.O. NO.:  
(AS APPLICABLE)

QTY.:  
(AS APPLICABLE)

CT RATIO:  
1600-1200-800/1-1-1-1-1

We reserve all rights in this document and in the information contained there in Reproduction, use or disclosure to third parties without express authority is strictly forbidden ©ABB.

Ⓐ New drg. prepared.

Ⓑ Change in sr no. 1,3

This drawing is a COMPUTER ORIGINAL and does not require signature for its authentication

| SR. NO. | REFERENCE OF STD DRGS/ DOCUMENTS | REV. | DESCRIPTION            |
|---------|----------------------------------|------|------------------------|
| 1.      | 1HYT903320-035                   | A    | GENERAL ARRANGEMENT    |
| 2.      | 1HYT903320-036                   | B    | RATING PLATE           |
| 3.      | 1HYT903320-037                   | B    | SECONDARY TERMINAL BOX |
| 4.      | 1HYT903320-038                   | A    | MAGNETIZATION CURVE    |

Chief Engineer/Construction

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.

|  |   |  |
|--|---|--|
| Prepared: SR                               | Checked: PDS                                | Approved: SN                                 |
| Without Sep. PL.: <input type="checkbox"/> | Same PL. Same No.: <input type="checkbox"/> | Sep. PL. Other No.: <input type="checkbox"/> |
| Derived by:                                | Supersedes:                                 | Supersedes by:                               |
| A 2021-01-12                               |   |  |
| B 2021-01-29                               |   |  |

LIST OF DOCUMENTS FOR  
IMB 145  
TYPE CT



Scale NTS






T.Sh. 1



1HYT903320-034

Sheets 1

**NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.**




\*HOT DIP GALVANISED ON OUTER SURFACE & PAINTED ON INNER SURFACE  
INNER SURFACE PAINTED WITH OIL RESISTIVE PAINT

| 18      | PRESSURE RELEASE DEVICE            | -       | SS / BRASS                        |
|---------|------------------------------------|---------|-----------------------------------|
| 17      | CORE STACK                         | -       | -                                 |
| 16      | PRIMARY WINDING                    | -       | PRIMARY CONDUCTOR (ALU)           |
| 15      | TRANSFORMER OIL                    | ~ 150kg | EHV GRADE - IEC:60296             |
| 14      | OIL EXPANSION SYSTEM               | 1       | TANK - ALU, EXP. SYSTEM - N2 GAS, |
| 13      | BOTTOM TANK AND TANK COVER         | 1       | M,S HDG*                          |
| 12      | LIFTING LUG                        | 4       | M,S HDG*                          |
| 11      | CONNECTION HEAD                    | 1       | ALU.                              |
| 10      | INSULATOR                          | 1       | PORCELAIN                         |
| 9       | NAME PLATE                         | 1       | ALU.                              |
| 8       | CENTRE OF GRAVITY                  | -       | -                                 |
| 7       | EARTH CLAMP                        | 4       | S.S. WELDED OVER M.S.             |
| 6       | OIL LEVEL INDICATOR                | 1       | TOUGHENED GLASS                   |
| 5       | OIL FILLING COVER                  | 1       | ALU.                              |
| 4       | OIL DRAIN PLUG WITH BLANKING PLATE | 1       | M,S HDG*                          |
| 3       | REMOVABLE UNDRILLED GLAND PLATE    | 1       | M,S HDG*                          |
| 2       | SECONDARY TERMINAL BOX             | 1       | M,S HDG*                          |
| 1       | PRIMARY TERMINAL                   | 2       | ALU.                              |
| Sr. No. | Item Description                   | Qty.    | Material                          |

## Chief Engineer/Construction

### NOTES:

- 1) DEVIATION FOR DIMENSIONS WITHOUT SPECIFIED TOLERANCES AS PER IS: 2102 - (EXTRA COARSE).
- 2) ALL NUTS, BOLTS AND WASHERS ARE OF STAINLESS STEEL/ MS HOT DIP GALVANIZED
- 3) ALL DIMENSIONS ARE IN mm.
- 4) TOTAL WEIGHT 1150 kg approx.
- 5) CREEPAGE DISTANCE 6125 mm.
- 6) ALL FERROUS PARTS EXPOSED TO ATMOSPHERE ARE HOT DIP GALVANIZED.
- 7) GENERAL TOLERANCE AS PER IS:2768-C



This document is COMPUTER ORIGINAL and does not need signature for its authentication

Revision Details:  
Ⓐ New drg. prepared.

We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. © ABB

|          |            |   |   |                   |              |              |                |             |
|----------|------------|---|---|-------------------|--------------|--------------|----------------|-------------|
| Revision |            | 245 kV OUTDOOR CURRENT TRANSFORMER TYPE IMB 245 | GENERAL ARRANGEMENT DRAWING (Medium Tank) | Prepared: SR      | Checked: SNP | Approved: SN | file: 3320-035 | Total sh. 1 |
| A        | 2021-01-12 |   |   | <b>ABB</b> APPSIL |              |              | 1HYT903320-035 | Sh.No. 1    |

Drawing approval subject to valid vendor registration

This drawing is a COMPUTER ORIGINAL and does not require signatures for its authentication


Revision Details:  
 (B) Typo error in aux. reactor note corrected.  
 Accuracy class revised to 0.2S

Revision Details:  
 (A) New drg prepared.

We reserve all rights in this document and in the information contained there in. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. © ABB.

**ABB** Current transformer      APPSIL      Production year - YYYY      Made in India

|                               |                |                               |                |                        |              |
|-------------------------------|----------------|-------------------------------|----------------|------------------------|--------------|
| Serial number                 | nnnnnn         | Type                          | IMB 245        | Frequency              | 50 Hz        |
| Insulation level              | 245/460/1050   | Standard                      | IEC: 61869-1,2 | Temperature range      | -5 to +50 °C |
| Rated pri. normal current     | 1600A          | Total mass(Approx)            | 1150 kg        | Total creepage minimum | 6125mm       |
| Max continous primary current | 1920A          | Insulation oil(Approx)        | 150 kg         | Ith                    | 40/1 kA/s    |
| GA Drawing                    | 1HYT903320-035 | Suitable for Hot line washing | Yes            | Idyn                   | 100 kAp      |



|           |                 |                 |                 |   |                 |
|-----------|-----------------|-----------------|-----------------|---|-----------------|
| RATIO     | 1600/1          | 1200/1          | 800/1           |   |                 |
| CORE-1    | 1S1-1S4         | 1S1-1S3         | 1S1-1S2         | <b>AUX. REACTOR CONNECTION DETAIL FOR CORE 5 ONLY</b><br>1.CONNECT SHORTING LINK BETWEEN 1X1-5S1 & 1X2-5S4 FOR THE RATIO OF 1600/1 RESPECTIVELY. TAKE OUTPUT FROM 1X1-1X2.<br>2.DO NOT CONNECT SHORTING LINK FOR THE RATIO OF 1200/1 & 800/1. |                 |
| CORE-2    | 2S1-2S4         | 2S1-2S3         | 2S1-2S2         |   |                 |
| CORE-3    | 3S1-3S4         | 3S1-3S3         | 3S1-3S2         |   |                 |
| CORE-4    | 4S1-4S4         | 4S1-4S3         | 4S1-4S2         |   |                 |
| CORE-5    | 5S1-5S4         | 5S1-5S3         | 5S1-5S2         |   |                 |
| CORE      | CORE-1          | CORE-2          | CORE-3          | CORE-4  | CORE-5          |
| I A       | 1600-1200-800/1 | 1600-1200-800/1 | 1600-1200-800/1 | 1600-1200-800/1   | 1600-1200-800/1 |
| Vk V/B VA | >1600/1200/800  | >1600/1200/800  | >1600/1200/800  | >1600/1200/800  | 20              |
| CI        | PX              | PX              | PX              | PX  | 0.2S            |
| ISF/ALF   | -               | -               | -               | -   | <5              |
| Io mA     | <15/20/30 at Vk | <15/20/30 at Vk | <15/20/30 at Vk | <15/20/30 at Vk   | -               |
| Rct Ω     | <8/6/4          | <8/6/4          | <8/6/4          | <8/6/4  | -               |

END CUSTOMER: APTRANSCO  
 ABB WORKS ORDER NO: (AS APPLICABLE)  
 PROJECT: (AS APPLICABLE)

Caution 1)Ensure D3(Tan Delta) Bushing connection with Earth  
 2)Secondary terminals must be short circuited before burden is disconnected


Serial number nnnnnn to be decided when manufactured  
 Production year yyyy = Actual year,date & month of Production      Drawing approval subject to valid vendor registration  
 Material: Aluminium 2mm Thk.  
 Letter height 3 mm

**NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.**


**Chief Engineer/Construction**

|          |            |   |              |                   |              |              |                |             |
|----------|------------|---|--------------|-------------------|--------------|--------------|----------------|-------------|
| Revision |            | 245 kV OUTDOOR CURRENT TRANSFORMER TYPE IMB 245 | RATING PLATE | Prepared: SR      | Checked: PDS | Approved: SN | File: 3320-036 | Total sh. 1 |
| A        | 2021-01-12 |   |              | <b>ABB APPSIL</b> |              |              | 1HYT903320-036 | Sh.No. 1    |
| B        | 2021-01-29 |   |              |                   |              |              |                | 1           |


NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.



Section-AA






D3=Tan  $\delta$  measuring terminal



S-Shorting link

AUX. REACTOR CONNECTION WITH CORE 5 (METERING)



Drawing approval subject to valid vendor registration

NOTES : -

- 1) DEGREE OF PROTECTION IP 55
- 2) THE SECONDARY TERMINAL BOX IS HOT DIP GALVANISED
- 3) D3 TERMINAL IS FOR THE MEASUREMENT OF POWER FACTOR AND LOSS ANGLE
- 4) THE BOX IS SUITABLE FOR ACCOMMODATING SECONDARY CABLES OF 1100 V
- 5) STEEL SHEET 3.15 mm THICK HOT ROLLED
- 6) ALL DIMENSIONS ARE IN mm. GENERAL TOLERANCE AS PER ISO: 2768-c
- 7) NO. OF WIRES SHOWN IN THE TERMINAL BLOCK ARE INDICATIVE ONLY

|        |                                  |
|--------|----------------------------------|
| 5      | COPPER WIRE                      |
| 4      | SERIES TERMINAL STUD TYPE        |
| 3      | EPDM GASKET                      |
| 2      | UNDRILLED GLAND PLATE (3mm Thk.) |
| 1      | COVER                            |
| SR NO. | ITEM DESCRIPTION                 |

**Chief Engineer/Construction**

We reserve all rights in this document and in the information contained there in. Reproduction or disclosure to third parties without express authority is strictly forbidden. @ABB.

Revision Details:  
 (B) Gland plate thickness added  
 BOTH created

Revision Details:  
 (A) New Drawing prepared

| Revision |            |  |
|----------|------------|--|
| A        | 2021-01-13 |  |
| B        | 2021-01-21 |  |

CURRENT TRANSFORMER  
 TYPE : IMB 245  
 SEC. TERMINAL BOX : DETAILS

DRAWN:  
 SR  
**ABB** APPSIL

CHECKED:  
 PDS


APPRD.:  
 SN

file: 3320-037

**1HYT903320-037**

TOTAL SH.  
 1  
 Sh. NO.  
 1

| Item | Core    | Current Ratio | Sec. Resistance At 75° C. Ohms | C1    | C2    |
|------|---------|---------------|--------------------------------|-------|-------|
| 10   | 1,2,3,4 | 1600/1        | <8                             | 16.49 | 0.048 |
|      |         | 1200/1        | <6                             | 12.37 | 0.064 |
|      |         | 800/1         | <4                             | 8.24  | 0.096 |
|      |         |               |                                |       |       |
|      |         |               |                                |       |       |
|      |         |               |                                |       |       |
|      |         |               |                                |       |       |
|      |         |               |                                |       |       |
|      |         |               |                                |       |       |



**Notes:**

1. The exciting current calculated from this graph does not take into account the current drawn by the protective device.
2. The values on the Voltage scale are to be multiplied by C1, while those on the current scale by C2.

Calculated Excitation Curve of Current Transformer

Type: **IMB245**

CORE 1,2,3,4 RATIO: 1600-1200-800/1, CLASS OF ACCURACY: PX  
 Vk >1600/1200/800 V, Rct < 8/6/4 Ohms, Io < 15/20/30mA at Vk

(A) New drg. prepared.

Drawing approval subject to valid vendor registration

**Chief Engineer/Construction**

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.

This document is COMPUTER ORIGINAL and does not need signature for its authentication

Drn: SR Chkd: PDS Apprd: SN



filename: 3320-038

1HYT903320-038

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.

**Annexure-A**  
**GUARANTEED TECHNICAL PARTICULARS FOR**  
**CURRENT TRANSFORMERS (245kV CT: 1600-1200-800/1-1-1-1 A)**

|         |  |  |
|---------|--|--|
| 1       | Type of tank/Installation<br>Dead/Live Tank Type   | Dead tank, Single phase, Oil Filled, Outdoor Type                                |
| 2       | Type of mounting   | Pedestal Mounting  |
| 3       | Manufacturer's Name and address<br>and Country of Manufacture                                      | APPSIL (Formerly - ABB India Ltd)<br>Maneja, Vadodara – 390013 India             |
| 4       | Whether Conforming to IEC 61869<br>standard  | Yes  |
| 5 a) i) | Primary and Secondary winding<br>made out of   | Primary – Aluminum,<br>Secondary – Copper  |
| ii)     | Primary windings<br>-Design density for short circuit<br>current -<br>Conductivity of metal used - | Aluminum<br>- 19.37 Amp/mm <sup>2</sup> (approx.)<br>- As per IEC                |
| b)      | i) Area of cross section of primary<br>winding   | 2065 mm <sup>2</sup> (approx.)   |
|         | ii) Area of cross section of<br>secondary winding  | PX : 1.17 mm <sup>2</sup> (approx.)<br>Metering : 0.82 mm <sup>2</sup> (approx.) |
| c)      | Material used for providing<br>secondary terminals   | Brass<br>(Primary Terminal will be Al)   |
| d)      | Material used for providing<br>secondary terminals   | Brass  |
| e)      | Whether Primary is Rigid Bar type<br>in case of live tank  | Not applicable   |
| 6       | Rated primary voltage (kV rms)   | 220 KV / root3   |
| 7       | Rated highest voltage (kV rms)   | 245 KV   |
| 8       | Rated frequency (Hz)   | 50 Hz  |
| 9       | Rated primary current (A)  | 1600-1200-800 A  |
| 10      | Rated secondary current (A)  | 1  |
| 11      | Ratio taps (on secondary side<br>only)   | On Secondary Side  |
| 12      | Type of insulation   | Class A  |
| 13      | Seismic acceleration (g)   | 0.3 g vertical   |
| 14      | RIV at 1.1 x Rated voltage (mv)  | < 500 micro volts  |
| 15      | Tank material and Tank coating   | Mild Steel, HDG  |
| 16      | Hardware exposed to atmosphere   | HDG  |
| 17      | Bolts, Nuts and Washers  | MS Hot dip galvanized.   |
| 18      | Porcelain housing and it make<br>(Single piece only)   | Hollow type,<br>IEC/BHEL/ABIL/ADI/Modern or Equivalent Make                      |
| 19      | Sealing (Nitrogen gas<br>cushion/Metal bellow  | Nitrogen cushion   |
| 20      | Instrument security factor   | <5 (For Metering core only)  |
| 21      | Whether Tan Delta test tap<br>provided   | Yes  |
| 22      | Whether secondary terminal plate<br>is of molded epoxy resin type                                  | Yes  |
| 23      | Whether primary terminal   | Molded cast resin & Porcelain  |

Drawing approval subject to valid vendor registration

**Chief Engineer/Construction**

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.

|        |  |  |                 |                 |                 |                 |
|--------|--|--|-----------------|-----------------|-----------------|-----------------|
|        | bushings are of molded Epoxy cast resin/Glass fiber reinforced Polymer                     |  |                 |                 |                 |                 |
| 24     | Whether all seals are of "O" ring type   | Yes "O" ring & Flat gasket   |                 |                 |                 |                 |
| 25     | Whether all "O" Rings are fixed in machined grooves with adequate space for compression'   | Yes  |                 |                 |                 |                 |
| 26     | Whether the main hollow insulator has the flanges cemented at both ends                    | Yes  |                 |                 |                 |                 |
| 27     | Whether "O" Rings are of Nitrile butyl rubber or Viton                                     | Yes (NBR)  |                 |                 |                 |                 |
| 28     | Whether the Short circuit Ampere-turns of the CT being supplied is same as type tested CTs | Yes  |                 |                 |                 |                 |
| 29     | Tan Delta  | Shall be less than 0.350%  |                 |                 |                 |                 |
| 30     | Whether ratio selection is achieved only in secondary                                      | Yes  |                 |                 |                 |                 |
| 31     | Whether ratio selection is achieved only in secondary                                      | Yes  |                 |                 |                 |                 |
| 32     | Whether Non return drain valve for oil sampling is arranged for 132kV and above CT/IVT     | Bolt Type  |                 |                 |                 |                 |
| 33     | Acceptable limit of temperature  | As per IS/IEC  |                 |                 |                 |                 |
| 34     | Partial Discharge Level  | < 5 at $U_m \times 1.2/\sqrt{3}$ , < 10 at $U_m$ (where $U_m$ is highest system voltage) |                 |                 |                 |                 |
| 35     | Rated short time withstand current for 1 sec. duration (kA rms)                            | 40 kA  |                 |                 |                 |                 |
| 36     | Rated dynamic withstand current (kAp)  | 100 kA   |                 |                 |                 |                 |
| 37     | Rated continuous thermal current (pu) where pu = rated current                             | 120% of rated primary current  |                 |                 |                 |                 |
| 38     | 1.2/50 micro second impulse withstand voltage (kVp)  | 1050   |                 |                 |                 |                 |
| 39     | One minute power frequency withstand voltage (kV rms) of primary winding (Dry)             | 460  |                 |                 |                 |                 |
| 40     | One minute power frequency withstand voltage of secondary winding (kV rms)                 | 3  |                 |                 |                 |                 |
| 41. a) | Minimum total creepage distance of insulator bushing (mm)                                  | 6125 mm (25mm/kV) Porcelain Insulator  |                 |                 |                 |                 |
| b)     | Protected creepage of distance of bushing (mm)   | Not Applicable   |                 |                 |                 |                 |
| 42     | Details of Cores   | Core-I   | Core-II         | Core-III        | Core-IV         | Core-V          |
| 42.1   | Current Ratios A/A   | 1600-1200-800/1  | 1600-1200-800/1 | 1600-1200-800/1 | 1600-1200-800/1 | 1600-1200-800/1 |
| 42.2   | Output burden (VA)   | -  | -               | -               | -               | 20              |

Drawing approval subject to valid vendor registration

**Chief Engineer/Construction**

|      |   |   |                    |                    |                    |             |
|------|---|---|--------------------|--------------------|--------------------|-------------|
| 42.3 | Class of accuracy   | PX  | PX                 | PX                 | PX                 | 0.2S        |
| 42.4 | Accuracy limit factor / ISF   | -   | -                  | -                  | -                  | <5          |
| 42.5 | Min. knee point voltage (kpv) in volts  | >1600-1200-800  | >1600-1200-800     | >1600-1200-800     | >1600-1200-800     | -           |
| 42.6 | Secondary resistance corrected to 75 deg.C in ohms  | 8-6-4@ Ohms   | 8-6-4@ Ohms        | 8-6-4@ Ohms        | 8-6-4@ Ohms        | -           |
| 42.7 | Max. Exciting current (mA) at<br>- 20% of knee point voltage<br>- 50% of knee point voltage<br>- 100% of knee point voltage | -<br>-<br>15-20-30  | -<br>-<br>15-20-30 | -<br>-<br>15-20-30 | -<br>-<br>15-20-30 | -<br>-<br>- |
| 42.8 | Application   | PX  | PX                 | PX                 | PX                 | Metr.       |
| 43   | Weight of oil (Kg.)   | 150 Kg (approx.)  |                    |                    |                    |             |
| 44   | Approximate weight of Copper used (Kgs)   | 27 Kg.  |                    |                    |                    |             |
| 45   | Approximate weight of Steel used (Kgs)  | 220 kg.   |                    |                    |                    |             |
| 46   | Total Weight (Kg.)  | 1150 kg (approx.)   |                    |                    |                    |             |
| 47   | Mounting details  | 450x450 (Please refer GA enclosed)                            |                    |                    |                    |             |
| 48   | Overall dimensions  | Please refer GA drawing enclosed                              |                    |                    |                    |             |
| 49   | Characteristics (whether graphs enclosed):  |   |                    |                    |                    |             |
| a)   | Ratio and phase angle curves  | Yes   |                    |                    |                    |             |
| b)   | Magnetization curves  | Yes   |                    |                    |                    |             |
| c)   | Ratio correction factor curves  | NA  |                    |                    |                    |             |
| 50   | Core  |   |                    |                    |                    |             |
| a)   | Area of cross section (sq.cm.)  | 37.12 sq. cm. (PX Core)                                       |                    |                    |                    |             |
| b)   | Flux density at rated primary current and rated burden  | As per Standard design practice                               |                    |                    |                    |             |
| c)   | Grade   | M4 (Or equivalent) For PX Core<br>Nano Core For Metering Core |                    |                    |                    |             |

## Chief Engineer/Construction

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS, TO BE CHECKED DURING ACCEPTANCE TESTS.

Drawing approval subject to valid vendor registration