


830 ± 75




**NOTES :-**


1. MAKE OF BUSHING: IEC/MODERN/ABI/BHEL/CJI
2. ALL FERROUS PART EXPOSED TO THE ATMOSPHERE SHALL BE PAINTED WITH P.U PAINT SHADE 631 OF IS:5
3. ALL GASKETS SHALL BE FIXED IN PROPERLY MACHINED GROOVES.
4. PRIMARY WINDING SHALL BE BAR TYPE.
5. ALL HARDWARE SHALL BE HOT DIP GALVANIZED.
6. TRANSFORMER OIL AS PER IEC : 60296.
7. ALL GASKETS SHALL BE MADE OF NITRILE BUTYL RUBBER.
8. TOTAL WEIGHT OF CT :- 350 kg. (APPROX.)
9. QUANTITY OF OIL :- 90 LITRES (APPROX.)
10. TOTAL CREEPAGE DISTANCE :- 3625 mm. (MINIMUM)
11. CORE/SECONDARY WINDINGS SHALL BE ENCASED IN ALUMINUM SHELL.

Drawing approval subject to valid vendor registration

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS. TO BE CHECKED DURING ACCEPTANCE TESTS.



S.No.	DESCRIPTION	MATERIAL	QTY
1	OIL FILLING PORT	M.S	1
2	BELLOW	S.S	1
3	BELLOW DOME	M.S/AL	1
4	OIL LEVEL INDICATOR	BRASS/AL.	1
5	PRIMARY TERMINAL	ALUMINUM	1
6	OIL TANK WITH COVER	M.S	1
7	BUSHING FLANGE	G/CI	2
8	BUSHING	PORCELAIN	1
9	BASE	M.S	1
10	SECONDARY TERMINAL BOX	M.S	1
11	LIFTING HOOK	M.S	4
12	EARTHING FLAT 80X50X8THICK.	M.S	2
13	NAME AND RATING PLATE	AL. ANODIZED	1
14	MOUNTING HOLE, Ø16 ± 2 mm	M.S	4
15	OIL DRAIN PLUG	M.S	1



Chief Engineer  
Projects

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED  
PROJECT NAME : AS APPLICABLE

REV.	FOR APPROVAL	DATED	SHEET NO.
00	FOR APPROVAL	08.02.2024	1 OF 7
	REVISION DESCRIPTION	INITIALS	

UNLESS OTHERWISE SPECIFIED  
1. ALL DIMENSIONS ARE IN mm  
2. TOLERANCE WHEREVER NOT INDICATED: ±5%

DATE	NAME	MATERIAL
08.02.2024	SPS	SEE TABLE
08.02.2024	AKASH	
08.02.2024	BIS	

TITLE : GENERAL ARRANGEMENT DRAWING FOR 132KV CURRENT TRANSFORMER RATIO : 800-1200/1A, 3 CORE BAR TYPE CT

SCALE : N.T.S




DRG.NO : ME-132CT-GA-01

MEHRU ELECTRICAL & MECHANICAL ENGINEERS PVT. LIMITED


Drawing approval subject to valid vendor registration

NOTES :-

1. MAKE OF BUSHING: IEC/MODERN/ABIL/BHEL/CJI
2. ALL FERROUS PART EXPOSED TO THE ATMOSPHERE SHALL BE PAINTED WITH P.U PAINT SHADE 631 OF IS:5
3. ALL GASKETS SHALL BE FIXED IN PROPERLY MACHINED GROOVES.
4. PRIMARY WINDING SHALL BE BAR TYPE.
5. ALL HARDWARE SHALL BE HOT DIP GALVANIZED.
6. TRANSFORMER OIL AS PER IEC : 60296.
7. ALL GASKETS SHALL BE MADE OF NITRILE BUTYL RUBBER.
8. TOTAL WEIGHT OF CT :- 350 kg. (APPROX.)
9. QUANTITY OF OIL :- 90 LITRES (APPROX.)
10. TOTAL CREEPAGE DISTANCE :- 3625 mm. (MINIMUM)
11. CORE/SECONDARY WINDINGS SHALL BE ENCASED IN ALUMINUM SHELL.



MOUNTING DETAILS



MOUNTING DETAILS

Chief Engineer  
Projects

S.No.	DESCRIPTION	MATERIAL	QTY
1	OIL FILLING PORT	M.S	1
2	BELLOW	S.S	1
3	BELLOW DOME	M.S/AL.	1
4	OIL LEVEL INDICATOR	BRASS/AL.	1
5	PRIMARY TERMINAL	ALUMINUM	1
6	OIL TANK WITH COVER	M.S	1
7	SECONDARY TERMINAL	Brass+Polyamide	---
8	BUSHING	PORCELAIN	1
9	BASE	M.S	1
10	SECONDARY TERMINAL BOX	M.S	1
11	LIFTING HOOK	M.S	4
12	EARTHING FLAT 80x50x8THICK	M.S	2
13	NAME AND RATING PLATE	AL. ANODIZED	1
14	MOUNTING HOLE, Ø16 ± 2 mm	M.S	4
15	OIL DRAIN PLUG	M.S	1

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED			
PROJECT NAME : AS APPLICABLE			
UNLESS OTHERWISE SPECIFIED	DATE	NAME	MATERIAL
1. ALL DIMENSIONS ARE IN mm	DGN. 08.02.2024	SPS	SEE TABLE
2. TOLERANCE WHENEVER NOT INDICATED: ±5%	DRN. 08.02.2024	AKASH	
	CHD. 08.02.2024	BLS	

TITLE		SCALE	
SECTIONAL ARRANGEMENT DRAWING FOR 132KV CURRENT TRANSFORMER RATIO : 800-1200/1A, 3 CORE BAR TYPE CT		N.T.S	
DRG.NO	ME-132CT-SE-01	DRG.NO	
REV.	REVISION DESCRIPTION	DATE	INITIALS
	FOR APPROVAL	08.02.2024	
SHEET No. 2 OF 7			

8546515/2024/EEMRT-ENE51



MEHRU ELECTRICAL & MECHANICAL ENGINEERS PVT. LIMITED



Drawing approval subject to valid vendor registration



**LIVE TANK CURRENT TRANSFORMER**  
MADE TO IS : 16227

HIGHEST SYSTEM VOLTAGE	145 kV	INSULATION LEVEL	275/650 kV
RATED S.T.C	31.5 KA for 1 Second	RATED FREQUENCY	50 Hz
NOMINAL SYSTEM VOLTAGE	132 kV	CORE 1	CORE 2
	800-1200	800-1200	800-1200
RATIO	PRIMARY(Amp)	800-1200	CORE 3
	SECONDARY(Amp)	1	1
SECONDARY TERMINALS	1S1-1S2-1S3	2S1-2S2-2S3	3S1-3S2-3S3
RATED BURDEN IN V.A	20 VA	20 VA	20 VA
ACCURACY CLASS	5P	PS	0.2S
ALF/ISF	20	----	<5 @All Tap
Min. knee point voltage	@1200A	60I(Rct+10)V	----
Max. Rct at 75°C	@1200A	6 Ω	----
Max. Iext at V <sub>k</sub>	@1200A	75 mA	----
YEAR OF MANUFACTURE	2024	SERIAL NO.	----

**RATED CONTINUOUS THERMAL CURRENT : 120% OF THE RATED PRIMARY CURRENT**

TOTAL WEIGHT OF CT :- 350 kg. APPROX. , QUANTITY OF OIL :- 90 LITRES APPROX.  
TOTAL CREPAGE DISTANCE :- 3625 mm. MINIMUM.

MADE IN INDIA BY


**MEHRU ELECTRICAL AND MECHANICAL ENGINEERS (P) LTD.**

SP-2/180, RITCO INDUSTRIAL AREA, KEHRANI, BHIWADI-301019, RAJASTHAN (INDIA)

225 ±15

**SUITABLE FOR HOT LINE WASHING**

**CONNECTION DIAGRAM**



**CAUTION:**

- 1) SHORT CIRCUIT AND EARTH ALL SECONDARY TERMINALS WHICH ARE NOT IN USE.
- 2) ALWAYS KEEP TAN DELTA TESTING TERMINAL 'C' SHORTED TO EARTH DURING OPERATION.
- 3) DO NOT REMOVE EARTH LINK WHEN IN OPERATION.

**NOTES:-**

1. THICKNESS OF NAME PLATE 1.2 mm
2. MATERIAL OF NAME PLATE SHALL BE AL. ANODIZED.
3. SERIAL NUMBER SHALL BE ENGRAVED BEFORE THE DISPATCH.

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS.




TO BE CHECKED DURING ACCEPTANCE TESTS.

REV.	FOR APPROVAL	DATED
	REVISION DESCRIPTION	INITIALS

Chief Engineer  
Projects

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED			
PROJECT NAME : AS APPLICABLE			
UNLESS OTHERWISE SPECIFIED	DATE	NAME	MATERIAL
1. ALL DIMENSIONS ARE IN mm	DGN, 08.02.2024	SPS	
2. TOLERANCE WHEREVER NOT INDICATED: ±5%	DRN, 08.02.2024	AKASH	AL. ANODIZED
	CHD, 08.02.2024	BLS	
TITLE		SCALE	
NAME PLATE DRAWING FOR 132KV CURRENT TRANSFORMER RATIO : 800-1200/1A, 3 CORE BAR TYPE CT		N.T.S	
SHEET No. 3 OF 7		DRG.NO ME-132CT-NP-01	





MATERIAL: POLYAMIDE  
MAKE: ELMEX  
**TERMINAL (DETAIL)**

**NOTES:-**

1. SECONDARY TERMINAL BOX SHALL BE PROVIDE WITH REMOVABLE GLAND PLATE WITHOUT HOLE.
2. SECONDARY TERMINAL BOX SHALL BE PROVIDED WITH COVER.
3. M.S SHEET THICKNESS FOR TERMINAL BOX SHALL BE 3.0mm & FOR COVER 2.0mm.
4. MATERIAL OF GASKET : EPDM/NITRILE BUTYL RUBBER GASKET.
5. DEGREE OF PROTECTION : IP 55.
6. 20% SPARE TERMINAL SHALL BE PROVIDED.

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS.  
TO BE CHECKED DURING ACCEPTANCE TESTS.

Chief Engineer  
Projects

Drawing approval subject to valid vendor registration

CLIENT : TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED		PROJECT NAME : AS APPLICABLE	
UNLESS OTHERWISE SPECIFIED			
1. ALL DIMENSIONS ARE IN mm			
2. TOLERANCE WHEREVER NOT INDICATED: ±5%			
REV.	FOR APPROVAL	DATED	INITIALS
RO		08.02.2024	
REV.	REVISION DESCRIPTION		
SHEET No. 4 OF 7		TITLE	
SECONDARY TERMINAL BOX DRAWING		FOR 132kV CURRENT TRANSFORMER	
RATIO : 800-1200/1A, 3 CORE		BAR TYPE CT	
DRG.NO	ME-132CT-STB-01	SCALE	N.T.S
MEHRU ELECTRICAL & MECHANICAL ENGINEERS PVT. LIMITED		MEHRU	

8546515/2024/EMRT-ENE51 plinth shall be maintained for CT/PT/CVT/Isolators in the substation during foundation works to ensure safe live to ground clearances as per IE rules.

2) Since the supply of terminal connectors is not in the scope of manufacturer as mentioned in the drawings, the EPC contractors shall be instructed to supply the same in line with CT/PT/CVT/Isolators requirement and compatibility.

Guaranteed Technical Particulars for 132kV Current Transformer			
Sl. No.	Item Description	Unit	GTP as per Bid
<b>E</b>	<b>CURRENT TRANSFORMER</b>		
1	Make		Mehru Electrical & Mechanical Engineers (P)Ltd, Bhiwadi, (Raj), Inida
2	Type and Designation		Outdoor, Oil Cooled Live Tank Type, Current Transformer
3	Applicable standards		IS 16227
4	Class		A
5	Rated Voltage	132 kV	132 kV
6	Rated Primary current	Amps	1200-800A
7	Rated Secondary current	Amps	1
8	Rated output (Burden)	VA	Core:-1 : 20 VA, Core-2: NA Core-3: 20 VA
9	Rated output at 0.8 lag. p.f.	VA	N/A
10	Class of accuracy		Core:1 – 5P, Core-2: PS Core:3 – 0.2S
11	Accuracy limit factor		Core-1: 20
12	Knee point voltage @highest tap	Volts	Core-2: 60I (RCT+10)
13	CT Resistance of secondary winding corrected to 75deg.C @highest tap	Ohms	Core-2: 6 Ω
14	Magnetizing current at knee-voltage point @highest tap		Core-2: 75 mA
15	secondary limiting voltage	kV	As per IS 16227
16	Instrument security factor for winding meant formetering		Core-3-≤ 5 at all tap
17	One minute Power Frequency withstand test voltageof		
a)	Primary winding	kV (rms)	275
b)	Secondary winding	kV (rms)	3

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS.

TO BE CHECKED DURING ACCEPTANCE TESTS.

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS.

TO BE CHECKED DURING ACCEPTANCE TESTS.

18	Impulse wave withstand voltage of primary winding	kV (peak)	650
19	One minute dry P.F. withstand voltage of primarywinding	kV (rms)	275
20	Creepage distance	mm	25mm/kV i.e. 3625mm (Min.)
21	Rated continuous thermal current	Amps	120% of rated primary current
22	Ratios available at highest taps		Yes
23	Rated short time thermal current	kA (rms)	31.5 kA
24	Rated time for above	Sec.	1
25	Rated dynamic current for primary	kA (Peak)	78.75
26	Class of insulation		A
27	Max. Temperature rise over ambient of 50 deg.C at any part of oil	deg.C	50c max
28			
b)	Radio interference voltage		As per IS 16227 Clause 6.11.2 <2500uV
c)	Partial discharge level		<10 pC at Um & <5 pc at 1.2Um/v3
29	Temp. rise after passing short time thermal current for one second	deg.C	50c max
30	Current density in primary winding at		
a)	Normal rating		0.61 Amps/sqmm
b)	Short time rating of 1 Sec.		16.05 Amp/sqmm
c)	Dynamic rating		40.13 Amp/sqmm
31	Type of primary winding		Bar Type
32	No. of primary turns		1
33	No. of secondary turns		1200-800
35	Radio interference voltage	(micro volts)	
a)	with terminal connector mounted		<2500uV

## For EPC Contracts Only

b)	under test condition		<2500uV
36	Variation in ratio and phase angle error due to variation in		
a)	Voltage by 1%		N/A
b)	Frequency by 1 Hz.		N/A
37	Mounting details		450 X 450 mm
38	Source/grade of oil and standard with which it complies		EHV Grade
39	Quantity of insulating oil	Litres	90 LITRES (APPROX.)
40	Weight of Oil	kg	80 Kg
41	Total Weight including Oil	kg	350 kg. (APPROX.)
42	Overall dimensions (mm)		2550 ±75 X 1950 ±50 X 830 ±75 mm
43	Whether sealed (if so, type of sealing)		Yes, By SS BELLOW
44	Tan delta		<0.005

NOTE : DRAWING APPROVAL SUBJECT TO VALID TYPE TEST REPORTS.

TO BE CHECKED DURING ACCEPTANCE TESTS.

1) Minimum 300mm plinth shall be maintained for CT/PT/CVT/Isolators in the substation during foundation works to ensure safe live to ground clearances as per IE rules.

2) Since the supply of terminal connectors is not in the scope of manufacturer as mentioned in the drawings, the EPC contractors shall be instructed to supply the same in line with CT/PT/CVT/Isolators requirement and compatibility.

Chief Engineer  
Projects